

LEGEND:

EXISTING SURFACE LEVEL (mAHD) STORMWATER PIPE (EXISTING) EXISTING DOWNPIPE TO BE RETAINED = EDP 100x75 RHS DOWNPIPE FROM EAVES GUTTER WITH MIN EFFECTIVE CROSS-SECTION AREA OF 7,500mm² DIRECTION OF FLOW IN GUTTER PROPOSED/EXISTING ROOF AREAS

NOTES:

- 1. ALL DIMENSIONS TO BE CONFIRMED ON SITE. LEVELS AND SITE LAYOUT BASED ON COUNCIL APPROVED (DA2018/1173) ARCHITECTURAL PLANS BY BLUE SKY BUILDING DESIGNS DATED 11 APRIL 2018. CONSULT ENGINEER SHOULD ANY DISCREPANCY ARISE OR AS REQUIRED FOR COORDINATION WITH OTHER SERVICES.
- 2. LOCATION OF ALL SERVICES MUST BE CONFIRMED ON SITE PRIOR TO COMMENCEMENT OF EXCAVATION WORKS.
- 3. ALL STORMWATER DRAINAGE PIPES AND ASSOCIATED DEVICES ARE TO BE INSTALLED IN ACCORDANCE WITH RELEVANT STANDARDS, THE BUILDING CODE OF AUSTRALIA, MANUFACTURER'S RECOMMENDATIONS, SYDNEY WATER AND LOCAL COUNCIL REQUIREMENTS, AS APPLICABLE.
- 4. ALL INVERT LEVELS PROVIDED ON THIS DRAWING ARE REDUCED TO AHD AND BASED ON INTERPOLATED SURFACE LEVELS AND SYSTEM REQUIREMENTS. CONSULT ENGINEER IF CHANGES ARE REQUIRED.
- 5. IT IS RECOMMENDED THAT ALL DOWNPIPES TO BE FITTED WITH LEAF BEATER RAINHEADS OR AN EQUIVALENT EXCLUSION DEVICE TO MINIMISE DEBRIS IN SYSTEM.
- 6. PROVIDE MIN 25mm ANNULAR SPACE AROUND PIPEWORK CUT THROUGH FOOTINGS OR WALLS AND FILL SPACE WITH FLEXIBLE LINER. PROVIDE TWO FLEXIBLE JOINTS IN PIPEWORK AT 300mm AND 700mm FROM FACE OF FOOTING OR WALL. PENETRATIONS BELOW SURFACE LEVEL TO BE SEALED AND MADE WATERTIGHT. ALL RAINWATER AND STORMWATER PIPEWORK LAID WITHIN OR UNDER THE PROPOSED STRUCTURE IS TO BE DWV PIPE CHEMICALLY SEALED FOR PRESSURE FLOWS. PIPES FIXED TO SUBFLOOR STRUCTURES TO BE SECURED AT MIN 1000 CENTRES AND EITHER SIDE OF EACH JOINT OR FITTING TO PREVENT SAGGING OF PIPEWORK AND ENSURE CONTINUOUS FLOW TO OUTLET.
- 7. EAVES GUTTERS TO HAVE MINIMUM EFFECTIVE CROSS-SECTIONAL AREA AS INDICATED AND INSTALLED WITH MIN 1:500 FALL TO DOWNPIPES. EACH NEW DOWNPIPE TO SERVE NO MORE THAN 30m2 PLAN ROOF AREA.
- 8. GUTTER AND DOWNPIPE DESIGN MAY BE VARIED IN ACCORDANCE WITH AS3500.

The information contained on this drawing has been prepared for the exclusive use of the Client for this project. No liability or responsibility is accepted for use of this information by any third party or for any other project.

	<u> </u>		<u> </u>	
Α	ISSUED FOR CONSTRUCTION	KW	KW	27.02.19
ISSUE	DESCRIPTION	BY	APR	DATE

Waddington Consulting Pty Ltd

Structural and Civil Engineering Consultants Suite 6, Level 5, 22 Central Avenue Manly NSW P.O. Box 1044 Manly NSW 1655 Phone (02) 9976 0070 Fax (02) 9976 0095 Email enquiries@wadconsulting.com

PROPOSED ALTERATIONS & ADDITIONS at: 85 WARATAH PARADE, NARRAWEENA for: A & C PROVAN	DRAWN: K.W. SCALE: 1 FILENAME: 11595-(1.11 (A).DWG	2019 : 200 SIZE A3
STORMWATER MANAGEMENT PLAN		A