



curran-t electrical

Matthew Curran
0404 849 408
Lic: 192 647C

3 Jun 2020

PO BOX 323,
FRESHWATER, N.S.W,
2096

Mr Ken White and Mike Grinham
2 & 2A Jabiru Close, Mona Vale
NSW 2103

Certificate of compliance

This is to confirm that we have Installed 2 x smoke alarms in number 2A Jabiru Close Mona Vale and checked interconnect. Tested the 3 smoke alarms in 2 Jabiru Close Mona Vale.

All Smoke Alarms have been installed and comply with As 3786. Should you require any further information please don't hesitate to call on the number below.

Kind regards,

Matthew Curran

P: 0404 849 408

E: currantelectrical@gmail.com

W: currantelectrical.com.au
