

## Natural Environment Referral Response - Flood

Application Number:	DA2021/0318
Date:	19/04/2021
To:	Penny Wood
Land to be developed (Address):	Lot 501 DP 736679 , 14 South Steyne MANLY NSW 2095

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The proposed development is for alterations and additions to commercial premises. There are no proposed extensions of floor areas below the flood planning level. Subject to conditions the proposal is compliant with Council's development controls.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Flooding

In order to protect property and occupants from flood risk the following is required:

##### Flood Effects Caused by Development – A2

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level of 4.29m AHD.

##### Building Components and Structural Soundness – B1

All new development below the Flood Planning Level of 4.59m AHD shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

##### Building Components and Structural Soundness – B3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed to cut electricity supply during flood events.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Certification of Services (B3)**

Certification that new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections are located above the FPL and waterproofing of electrical equipment and installation of residual current devices below the Flood Planning Level (B3)

A suitably qualified electrical engineer or contractor is to certify that all new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections are located above the Flood Planning Level and any existing electrical devices, wiring and the like located below the FPL are protected from water egress or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.