

13/84 Old Pittwater Road  
Brookvale NSW 2100  
info@abate.com.au  
02 9939 8107

### Fire Safety Measures

Date: 09/11/2023

<i>Project Address:</i>	<b>13 The Corso Manly NSW 2095</b>
<i>Scope of Work:</i>	Inspection and certification of fire safety measures
<i>Certification</i>	Certification of fire safety measures as listed below to comply with BCA requirements and Australian Standards.
<i>Certification:</i>	<p>I, Damien McIlwraith of Abate Fire Protection Services certify that;</p> <ul style="list-style-type: none"> <li>Each of the building components relating to the discipline and scope of work identified above;</li> <li>has been accessed by me or a person (chosen by me) who was properly qualified to do so and was found when it was inspected. To have been in accordance with the design requirements to meet at least the minimum applicable Building Code of Australia requirements and/or the relevant Australian Standards. The applicable standards are listed below and can perform to a standard not less than required.</li> <li>Inspections and testing has been carried out and to the best of our knowledge the systems are operational.</li> <li>The information contained in this certificate is, to the best of my knowledge and belief, true and accurate.</li> </ul>

<i>Fire Safety Measures</i>	<i>Australian Standard/BCA Reference:</i>
Emergency lighting	AS 2293.1, BCA Clause E4.4, E4.2
Exit signs	AS 2293.1, BCA Clause E4.5, E4.8
Fire blanket	AS 2444
Portable fire extinguishers	AS 2444, E1.6 of the BCA
Smoke alarms	AS 3786



***Inspected by Damien McIlwraith***  
**Director - Abate Pty Ltd**

Accreditation number: F053933A  
Builder / Electrician License No. 188109C