

Engineering Referral Response

Application Number:	DA2021/0064
Date:	05/05/2021
To:	Kye Miles
Land to be developed (Address):	Lot 5 DP 12797 , 41 Wallumatta Road NEWPORT NSW 2106

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

25/03/2021:

Stormwater

The site is falling to the rear and proposal is to construct a secondary dwelling at rear and hard stand area at front for car parking.

The proposed development leads to total hardstand area more than 50sqm, an Onsite Stormwater Detention System is required.

All new storm water shall be collected and carried to rainwater tanks, located beneath the lower floor deck. Refer drg. No. 2001 – 02, 04 and WaterDesign Civil Engineers stormwater management design drawings Nos. 2020-073 /SW1 – 3

Above mentioned stormwater drawings in the Statement of Environmental Effects Report are not provided.

But before Council consider these drawings applicant is advised as below:

a) The Stormwater drainage for the site shall demonstrate compliance with Council's Water Management for Development Policy, particularly Stormwater Drainage from Low Level Properties Technical Specification Section 5.5. As the subject site falls to the rear, an easement to drain water is to be created in favor of the site over the downstream properties. Evidence of owners consent by the property owners (41 Irrubel Road) shall be submitted with the Development Application. The Application shall be supported by a long section of the inter-allotment drainage to the connection with Council's road drainage system.

b) Should this method of stormwater disposal not be possible, evidence shall be submitted with the Application.

For sample letter refer Appendix 2, Easement Letter of Council's Water Management for Development Policy.

Access

The architectural plans and landscape plans are contradictory to each other and do not show similar arrangement for car parking.

Applicant to provide amended plans.

05/05/2021:

Stormwater

An easement refusal letter is provided, TRIM 2021/305296.

Stormwater plans prepared by Water Design Civil Engineers, drawing number SW1 to SW3, Job No. 2020-073, dated 14-01-2021 are satisfactory.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by White Geotechnical Group, J3100, dated 02-12-2020 are to be incorporated into the construction plans. Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

On-site Stormwater Detention Details

The Applicant is to provide a certification of drainage plans detailing the provision of on-site stormwater detention in accordance with Northern Beaches Council's Water Management for Development Policy, and generally in accordance with the concept drainage plans prepared by Water Design Civil Engineers, drawing number SW1 to SW3, Job No. 2020-073, dated 14-01-2021 and also certify that the existing approved stormwater system can accommodate the additional flows. Detailed drainage plans are to be prepared by a suitably qualified Civil Engineer, who has membership to the Institution of Engineers Australia, National Professional Engineers Register (NPER) and registered in the General Area of Practice for civil engineering.

The drainage plans must address the following:

- i. OSD to be provided in accordance with Clause 9.0 of Council's Water Management for Development Policy.
- ii. Detailed drainage plans, including engineering certification, are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater and stormwater management arising from the development.

Vehicle Driveway Gradients

The Applicant is to ensure driveway gradients within the private property are not to exceed a gradient of 1 in 4 (25%) with a transition gradient of 1 in 10 (10%) for 1.5 metres prior to a level parking facility. Access levels across the road reserve are to comply with the allocated vehicle profile detailed in this consent.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure suitable vehicular access to private property.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Positive Covenant and Restriction as to User for On-site Stormwater Disposal Structures

The Applicant shall lodge a Legal Documents Authorisation Application with Council. The application is to include the original completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) and a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan by a Registered Surveyor) and Hydraulic Engineers' certification for the completed onsite stormwater detention system works. A guide to the process can be found on Council's website using the following link.

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detention-systems/guide-submitting-lda-anov19.pdf>

The form for the application can be found on Council's website using the following link.

[https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detention-systems/4023 legaldocumentsauthorisationoct19.pdf](https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detention-systems/4023%20legaldocumentsauthorisationoct19.pdf)

The Applicant shall create on the Title a positive covenant in respect to the ongoing maintenance and

restriction as to user over the on-site stormwater detention system within this development consent. The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgment with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant. A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user for the on-site stormwater detention system is to be submitted.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure the on-site stormwater disposal system is maintained to an appropriate operational standard and not altered.

Retaining wall

The retaining wall works shall be certified as compliant with all relevant Australian Standards and Codes by a Structural Engineer. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Final Occupation Certificate.

Reason: Public and Private Safety

Geotechnical Certification Prior to Occupation Certificate

The Applicant is to submit the completed Form 3 of the Geotechnical Risk Management Policy (Appendix 5 of P21 DCP) to the Principal Certifying Authority prior to issue of the Final Occupation Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.