

FIRE SAFETY SCHEDULE

DA No: 6000/6840

Shop Number/Name: *Shop 820 - Carnes Arcade*

Property Address: 145 Old Pittwater Road, BROOKVALE NSW 2100

Description of Development: Retail Tenancy Fitout

Essential fire safety measure		Standard of performance	
		Australian Standard	BCA Clause(s)
Access panels, doors & hoppers to fire resisting shafts		AS 1905.1 - 1997	C3.13
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Automatic fail safe devices		-	C3.8, D2.21, Spec C3.4
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Automatic fire detection & alarm systems (EWIS)		AS 1670 - 1995; AS 1603	Spec E2.2a
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Automatic fire suppression systems (Sprinklers)		AS 2118.1 - 1999	Spec E1.5
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Emergency lighting		AS/NZS 2293.1 - 1998	E4.4
EXISTING	PROPOSED		
<input type="checkbox"/>	<input checked="" type="checkbox"/>		
Emergency warning and intercommunication systems		AS 2220.1 & 2 - 1989	E4.9, Spec G3.8
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Exit signs		AS/NZS 2293.1 - 1998	E4.8
EXISTING	PROPOSED		
<input type="checkbox"/>	<input checked="" type="checkbox"/>		
Fire dampers		AS 1668, AS 1682	-
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Fire doors		AS/NZS 1905.1 - 1997	Spec C3.4
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Fire hydrant systems		AS 2419.1 - 1994	E1.3
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Fire seals protecting openings in fire resisting components		AS 4072.1, AS 1530.4; AS 1038.15	Spec C3.15
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Hose reel systems		AS 2441 - 1988	E1.4
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		

<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Lightweight construction		-	C1.8, Spec C1.8
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Mechanical air handling systems (air conditioning)		AS 1668.1 & 2 – 1991	F4.5, F4.11, F4.12
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Portable fire extinguishers & fire blankets		AS 2444 – 1995	E1.6
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Smoke and heat vents		AS 2665 – 1983	Spec E2.2c, Spec G3.8 & NSW H101.22
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Smoke dampers		AS 1668.1 & 2	-
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Smoke detectors & heat detectors		AS 1670 – 1995	Spec E2.2a
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		
Smoke doors		-	Spec C3.4
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Solid core doors		-	C3.11, NSW C3.11(d)(ii)
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Warning and operational signs		-	C3.6, E3.3, D2.23 & Spec E1.8
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Required (Automatic) Exit Doors		AS 1670.1 – 1995	Clause D2.19
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Sliding Fire Doors		-	Clause C3.6
EXISTING	PROPOSED		
<input type="checkbox"/>	<input type="checkbox"/>		
Smoke Control System		AS/NZS 1668.1 – 1998	Spec. E2.2a, E2.2b
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input type="checkbox"/>		

Dated: 26/07/10

Signed: 