

FIRE SAFETY SCHEDULE

*Prepared in accordance with clause 168 of the Environmental Planning & Assessment Regulation 2000
to accompany the subject Construction Certificate / Complying Development Certificate.*

Identification of building

Address: 2 BEACH RD, PALM BEACH

Description of Work: Existing Golf Club

Fire Safety & Other Measures	Existing Measure	Minimum Standards of Performance
Fire Hose Reels		BCA Cl. E1.4 - AS 2441
Portable Fire Extinguishers		BCA Cl E1.6, AS 24441 - 2001
Emergency lighting		BCA Part E4.2 & E4.4 AS/NZS 2293.1- 1995
Exit signs		BCA Part E4.5 & E4.6 & E4.8 AS/NZS 2293.1- 1995
Author	Kieran Tobin, BPB 0409	
Note – The development relies on a Street Fire Hydrant		