

TELEPHONE: 13 13 65
EMAIL: development@ausgrid.com.au



24-28 Campbell St
Sydney NSW 2000
All mail to
GPO Box 4009
Sydney NSW 2001
T +61 2 13 13 65
ausgrid.com.au

This letter is Ausgrid's response under section 2.48 of the State Environmental Planning Policy (Transport and Infrastructure) 2021.

Ausgrid consents to the development subject to the following conditions: -.

The applicant/developer should note the following comments below regarding any proposal within the proximity of existing electrical network assets.

Ausgrid Overhead Powerlines are in the vicinity of the development.

The developer should refer to SafeWork NSW Document – Work Near Overhead Powerlines: Code of Practice. This document outlines the minimum separation requirements between electrical mains (overhead wires) and structures within the development site throughout the construction process. It is a statutory requirement that these distances be maintained throughout the construction phase.

Consideration should be given to the positioning and operating of cranes, scaffolding, and sufficient clearances from all types of vehicles that are expected be entering and leaving the site.

The “as constructed” minimum clearances to the mains must also be maintained. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid's website at www.ausgrid.com.au.

It is the responsibility of the developer to verify and maintain minimum clearances onsite. In the event where minimum safe clearances are not able to be met due to the design of the development, the Ausgrid mains may need to be relocated in this instance. Any Ausgrid asset relocation works will be at the developer's cost.

New Driveways - Proximity to Existing Poles

Ausgrid Network standard NS167 requests that proposed driveways should be located to maintain a minimum clearance of 1.5 m from the nearest face of the pole to any part of the driveway, including the layback, to allow room for future pole replacements. Ausgrid should be further consulted for any deviation to this norm.

New or modified connection

To apply to connect or modify a connection for a residential or commercial premises Ausgrid recommends the proponent to engage an Accredited Service Provider and submit a connection application to Ausgrid as soon as practicable. Visit the Ausgrid website for further details;

<https://www.ausgrid.com.au/Connections/Get-connected>

Additional information can be found in the Ausgrid Quick Reference Guide for Safety Clearances "Working Near Ausgrid Assets - Clearances". This document can be found by visiting the following Ausgrid website:

www.ausgrid.com.au/Your-safety/Working-Safe/Clearance-enquiries

Should you require further information please contact Ausgrid via email to Development@ausgrid.com.au

Regards,
Ausgrid Development Team