## **BASIX** Certificate

Building Sustainability Index www.basix.nsw.gov.au

## Alterations and Additions

Certificate number: A361110

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretarv Date of issue: Tuesday, 15, October 2019 To be valid, this certificate must be lodged within 3 months of the date of issue.



| Project name                    | 19 Manly Rd   |
|---------------------------------|---|
| Street address                  | 19 manly Road seaforth 2092   |
| Local Government Area           | Northern Beaches Council  |
| Plan type and number            | Deposited Plan 204401   |
| Lot number                      | 1   |
| Section number                  |   |
| Project type                    |   |
| Dwelling type                   | Separate dwelling house   |
| Type of alteration and addition | My renovation work is valued at \$50,000 or mo<br>and does not include a pool (and/or spa). |

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: Uri T Design

ABN (if applicable): 61735627811

Ű **đ**)

| Fixtures and systems   | Show on<br>DA Plans | Show on<br>CC/CDC<br>Plans &<br>specs | Certifier<br>Check |
|--|---------------------|---------------------------------------|--------------------|
| Hot water  |                     |                                       |                    |
| The applicant must install the following hot water system in the development: gas instantaneous.   | $\checkmark$        | $\checkmark$                          | $\checkmark$       |
| Lighting   |                     |                                       |                    |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps. |                     | ~                                     | ~                  |
| Fixtures   |                     |                                       |                    |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating.                                |                     | $\checkmark$                          | $\checkmark$       |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating.                     |                     | $\checkmark$                          | $\checkmark$       |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.                                 |                     | $\checkmark$                          |                    |

| Construction  |  |                                   | Show on<br>DA Plans | Show on<br>CC/CDC<br>Plans &<br>specs | Certifier<br>Check |
|---|--|-----------------------------------|---------------------|---------------------------------------|--------------------|
| Insulation requirements   |  |                                   |                     |                                       |                    |
| The applicant must construct the new or altered<br>the table below, except that a) additional insula<br>is not required for parts of altered construction | ~  | ~                                 | ~                   |                                       |                    |
| Construction  | Additional insulation required (R-value)               | Other specifications              |                     |                                       |                    |
| floor above existing dwelling or building.  | nil  |                                   |                     |                                       |                    |
| external wall: framed (weatherboard, fibro, metal clad)   | R1.30 (or R1.70 including construction)                |                                   |                     |                                       |                    |
| raked ceiling, pitched/skillion roof: framed  | ceiling: R1.00 (up), roof: foil backed blanket (55 mm) | light (solar absorptance < 0.475) |                     |                                       |                    |
| flat ceiling, flat roof: framed   | ceiling: R0.90 (up), roof: foil backed blanket (55 mm) | light (solar absorptance < 0.475) |                     |                                       |                    |

| Glazing requ  | irements   |   |                          |                             |   |  | Show on<br>DA Plans | Show on<br>CC/CDC<br>Plans &<br>specs | Certifier<br>Check |
|---|--|---|--------------------------|-----------------------------|---|--|---------------------|---------------------------------------|--------------------|
| Windows and   | d glazed do  | ors                                       |                          |                             |   |  |                     |                                       |                    |
|   |  |   |                          |                             | hading devices, in accordar<br>r each window and glazed ( | nce with the specifications listed in the table below.<br>door.  | $\checkmark$        | $\checkmark$                          | $\checkmark$       |
| The following re  | equirements  | must also                                 | be satisf                | ed in relation              | n to each window and glaze                                | ed door:   |                     | $\checkmark$                          | $\checkmark$       |
| have a U-value<br>must be calcula   | and a Solar  | Heat Gair<br>dance with                   | n Coefficio<br>Nationa   | ent (SHGC)<br>I Fenestratio | no greater than that listed ir                            | r gap/clear glazing, or toned/air gap/clear glazing must<br>n the table below. Total system U-values and SHGCs<br>onditions. The description is provided for information |                     | ~                                     | ~                  |
|   |  |   |                          |                             | f each eave, pergola, veran<br>than 2400 mm above the si  | idah, balcony or awning must be no more than 500 mm<br>ill.  | ~                   | $\checkmark$                          | $\checkmark$       |
| External louvres and blinds must fully shade the window or glazed door beside which they are situated when fully drawn or closed.   |  |   |                          |                             |   |  | $\checkmark$        | $\checkmark$                          |                    |
|   | Pergolas with adjustable shading may have adjustable blades or removable shade cloth (not less than 80% shading ratio). Adjustable blades must overlap in plan view. |   |                          |                             |   |  |                     | $\checkmark$                          | $\checkmark$       |
| Overshadowing buildings or vegetation must be of the height and distance from the centre and the base of the window and glazed door, as specified in the 'overshadowing' column in the table below. |  |   |                          |                             | $\checkmark$  | ~  | $\checkmark$        |                                       |                    |
| Windows ar  | nd glazed  | doors g                                   | lazing r                 | equireme                    | nts   |  | _                   |                                       |                    |
| Window / door<br>no.  | Orientation  | Area of<br>glass<br>inc.<br>frame<br>(m2) | Oversha<br>Height<br>(m) | adowing<br>Distance<br>(m)  | Shading device  | Frame and glass type   |                     |                                       |                    |
| G-W1  | S  | 16  | 0                        | 0                           | none  | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)  |                     |                                       |                    |
| G-W2  | N  | 3.6                                       | 3                        | 0.1                         | none  | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46)   |                     |                                       |                    |
| F-W1  | S  | 5.2                                       | 0                        | 0                           | none  | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46)   |                     |                                       |                    |
| F-W2  | S  | 6.9                                       | 0                        | 0                           | none  | improved aluminium, single pyrolytic low-e,  |                     |                                       |                    |

| Glazing requirements      |             |   |               |                 |  |  | Show on<br>DA Plans | Show on<br>CC/CDC<br>Plans &<br>specs | Certifier<br>Check |
|---------------------------|-------------|---|---------------|-----------------|--|--|---------------------|---------------------------------------|--------------------|
| Window / door Orie<br>no. | Orientation | ation Area of<br>glass<br>inc.<br>frame<br>(m2) | Oversha       |                 | Shading device                         | Frame and glass type   |                     |                                       |                    |
|                           |             |   | Height<br>(m) | Distance<br>(m) |  |  |                     |                                       |                    |
|                           |             |   |               |                 |  | (U-value: 4.48, SHGC: 0.46)  |                     |                                       |                    |
| F-W3                      | E           | 1.5   | 3             | 0.2             | none                                   | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W4                      | S           | 6.5   | 0             | 0               | none                                   | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)    |                     |                                       |                    |
| F-W5                      | E           | 2.9   | 0             | 0               | external louvre/blind (adjustable)     | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W6                      | E           | 4.5   | 0             | 0               | external louvre/blind (adjustable)     | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W7                      | E           | 1.4   | 0             | 0               | external louvre/blind (fixed)          | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W8                      | Ν           | 5.3   | 0             | 0               | pergola (adjustable shade) >=900<br>mm | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W9                      | W           | 3   | 0             | 0               | pergola (adjustable shade) >=900<br>mm | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W10                     | Ν           | 8   | 0             | 0               | pergola (adjustable shade) >=900<br>mm | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W11                     | N           | 5.3   | 0             | 0               | pergola (adjustable shade) >=900<br>mm | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W12                     | W           | 1.2   | 2.5           | 2.5             | none                                   | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |
| F-W13                     | W           | 2.4   | 2.5           | 2.5             | none                                   | improved aluminium, single pyrolytic low-e,<br>(U-value: 4.48, SHGC: 0.46) |                     |                                       |                    |

## Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a "" in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a " " in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.