

Natural Environment Referral Response - Riparian

Application Number:	DA2018/1991
To:	Nick England
Land to be developed (Address):	<p>Lot 9 DP 629464 , 104 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 8 DP 629464 , 102 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 15 DP 858130 , 100 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 14 DP 858130 , 96 Cabarita Road AVALON BEACH NSW 2107</p>

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application is recommended for approval.

Stormwater quality management has been incorporated into the common property. The boundary pit on this lot will be incorporated into the community management statement and will be retained and maintained as part of the subdivision community title stormwater quality management system.

Sediment and erosion controls must be installed prior to any work on the site and maintained until work is complete and groundcover has been re-established.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban

Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site (DACNED06)