

Building Assessment Referral Response

Application Number:	DA2022/1028
Date:	10/08/2022
To:	Thomas Burns
Land to be developed (Address):	Lot 2 DP 212320 , 43 Hilltop Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no concerns with the application subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

National Construction Code (BCA) Report

A BCA Report was not provided with the application. A 'Building Code of Australia (NCC/BCA) Assessment Report' from an appropriately qualified Registered Certifier* will need to be submitted with the Construction Certificate application addressing the following:

The report is to detail the extent to which the existing building (relevant affected parts) does or does not comply with the deemed-to satisfy provisions of Volume **Two** of the Building Code of Australia. The report is to also provide recommendations with respect to the existing building / works required to ensure that the specified measures and facilities contained in the existing building, including any modifications to be made by the proposed development are appropriate for its intended use to:

- i) restrict the spread of fire from the building to other buildings nearby, and
- ii) protect persons using the building, and to facilitate their egress from the building in the event of fire,
- iii) ensure occupant safety and amenity; and
- iii) provide facilities and services appropriate for the development

**To be regarded as an "appropriately qualified registered certifier" the certifier must hold the relevant level of accreditation that would enable the certifier to issue a construction certificate for the subject building.*

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety