

## Natural Environment Referral Response - Riparian

<b>Application Number:</b>	DA2019/1384
<b>To:</b>	Benjamin Price
<b>Land to be developed (Address):</b>	Lot 4B DP 13374 , 1130 Barrenjoey Road PALM BEACH NSW 2108

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

This application has been assessed under  
Pittwater 21 DCP B5.8 Water Quality  
Pittwater 21 DCP B8.2 Sediment and Erosion Control  
SEPP Coastal Management 2018 - Coastal Environment Zone

This application will not increase impervious area by more than 50sqm, therefore water quality controls do not apply.

Sediment and erosion controls must be installed prior to any work on site and maintained until all work is complete and groundcover re-established.

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Recommended Natural Environment Conditions:

#### CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

#### Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.