

## GEOTECHNICAL CERTIFICATION

26 Meehan Road, Cromer NSW

AscentGeo have reviewed the calculations resulting from constant head permeameter testing carried out by Taylor Consulting Engineers to determine design infiltration rates for the installation of a proposed on-site absorption system.

The proposed stormwater infiltration system, as designed by Taylor Consulting Engineers should result in no significant geotechnical risk to property or life and is considered 'ACCEPTABLE' with reference to Australian Geomechanics Society Guidelines.

We are in support of the proposed system, and the adoption of an infiltration rate of 0.1 L/s/m<sup>2</sup>.

If you have any questions or require any clarification, please call 9913 3179.

For and on behalf of **AscentGeo** Geotechnical Consulting,



**Ben Morgan** BScGeol MAIG RPGeo  
Managing Director | Engineering Geologist

