

Grant Harding

Ref: 1009182 - ESD review letter

Date: 23rd June 2015

Cerno Management
Suite 2, Level 4
280 George St, Sydney
NSW 2000

Dear Grant,

RE: Harbord Diggers
Environmental Sustainability & Social Impact Report statement

This letter serves to confirm that Cundall has reviewed the Environmental Sustainability & Social Impact Report (Revision No. 4 – DA Submission) and that the report still reflects the current state of documentation for the Section 96, with a few minor amendments. These amendments are as follows:

- Showerheads are 3-Star <9L/min rather than <7.5L/min;
- Bathroom taps are 3-Star rather than 6-Star;
- Rainwater tank is 50,000L instead of 131,000L;
- Green roofs have been removed from the buildings.

The BASIX documentation has been updated according to the revised design documentation is attached, including:

- Updated BASIX Certificate;
- Updated NatHERS certification;
- Updated certified drawings.

We trust the foregoing is adequate for your purposes, but should you have any questions please do not hesitate to contact me.

Yours sincerely,

For and on behalf of Cundall



Hannah Morton
Senior ESD Consultant
email: h.morton@cundall.com.au
tel: 8424 7017