

Building Assessment Referral Response

Application Number:	DA2020/0182
Date:	11/03/2020
To:	Jordan Davies
Land to be developed (Address):	Lot 6 DP 30579 , 45 Mitchell Road BROOKVALE NSW 2100

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Change of Use - Fire Safety Upgrade

The Building Code of Australia works and fire upgrading measures to upgrade the building as detailed and recommended in the Building Code of Australia Compliance Audit Report prepared by Private Certifiers Australia, dated 27/02/2020, are to be taken into consideration as part of the Construction Certificate assessment.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

Access for People with Disabilities

Access to and within the building is to be provided for Persons with a Disability. In particular the front entrance doorway and off-street car parking are to comply with the Building Code of Australia and AS 1428.1.

Details are to be provided to the Certifying Authority prior to the issue of the Construction Certificate and be implemented prior to occupation of the building.

Reason: To ensure adequate provision is made for access to and within the building for Persons with a disability.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE****Fire Safety Matters**

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.