

## Engineering Referral Response

<b>Application Number:</b>	DA2020/1608
<b>Date:</b>	04/01/2021
<b>To:</b>	Kelsey Wilkes
<b>Land to be developed (Address):</b>	Lot 6 DP 21756 , 9 Milga Road AVALON BEACH NSW 2107

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m<sup>2</sup> or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

The proposed swimming pool requires excavation greater than 1.0m, which requires submission of a geotechnical report and risk assessment, including forms 1 and 1(a) in accordance with Pittwater clause B3.1 Pittwater 21 DCP. As a result the application cannot be supported due to lack of information.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Engineering Conditions:

Nil.