

## Parks, Reserves and Foreshores Referral Response

<b>Application Number:</b>	DA2025/0026
<b>Proposed Development:</b>	Alterations and additions to a dwelling house including a swimming pool
<b>Date:</b>	29/01/2025
<b>To:</b>	Simon Ferguson Tuor
<b>Land to be developed (Address):</b>	Lot 17 DP 30849 , 17 Egan Place BEACON HILL NSW 2100

### Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore

And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

### Officer comments

The development site adjoins Egan Reserve that is located downslope of the property. All development works must ensure that surface sediment runoff and/or erosion is controlled, managed and contained within the site boundaries and prevented from travelling across the boundary and into the Reserve.

For information purposes it is noted that existing encroachments (ie. fencing) occur into the public reserve, as shown on the Survey Plan. Any approval of this development application does not regularise any unauthorised encroachments within the public reserve.

The existing property at the rear includes low height retaining wall with fencing above this, and the proposal is likewise a similar proposal and no concerns are raised however any development works shall be wholly contained within the residential lot boundaries.

The proposal includes removal of weed species in Reserve, and this matter is deferred to Council's Bushland & Biodiversity Referral team.

Parks Reserves and Foreshores Referral raise no concerns in terms of the transition between private and public land in consideration of Warringah DCP control E7 Development on land adjoining public open space, as the existing and proposed treatment at the boundary is similar. Public access to the Reserve is not impacted by the proposed development and the development is not detrimental to the prevailing landscape character when viewed from the adjoining Reserve.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Parks, Reserves and Foreshores Conditions:

## CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

### Works on Land Owned or Managed By Council

No works are to be carried out on land owned or managed by Council.

Note: Separate approval from Council is required for access driveways, paths, stairs, connections to underground utilities (stormwater, gas, sewer, electricity, telecommunications etc.) and landscaping works on land owned or managed by Council.

Reason: To protect the land owned or managed by Council.

### **Installation and Maintenance of Sediment and Erosion Control**

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period. Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

### **Protection of Trees on Land Owned or Managed by Council**

Unless identified by the development consent, existing trees on Council Land shall be protected in accordance with AS4970- 2009 Protection of trees on development sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance.

Reason: Tree protection and management.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **No Access Through Land Owned or Managed by Council**

Site access is not approved for delivery of materials nor construction of the development through adjacent land owned or managed by Council, without the written approval of Council.

Reason: Public safety, landscape amenity and tree protection.

### **Storage of Materials on Land Owned or Managed by Council Prohibited**

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

### **Protection of Council's Public Assets**

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993. Existing trees shall be protected in accordance with AS4970-2009 Protection of Trees on Development Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor

canopy disturbance.

Reason: To protect and/or restore any damaged public asset.