

## Natural Environment Referral Response - Coastal

<b>Application Number:</b>	DA2024/1671
<b>Proposed Development:</b>	Alterations and additions to a dwelling house including swimming pool and cabana
<b>Date:</b>	07/01/2025
<b>Responsible Officer</b>	Anaiis Sarkissian
<b>Land to be developed (Address):</b>	Lot 1 DP 207313 , 99 Riverview Road AVALON BEACH NSW 2107

### Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

SUPPORTED WITH CONDITIONS

This application was assessed in consideration of:

- Supplied plans and reports;
- State Environmental Planning Policy (Resilience and Hazards) 2021 (section 2.10, 2.11 & 2.12);
- Relevant LEP and DCP clauses.

### State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021. Hence, Clauses 2.10, 2.11 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by JS Urban Design dated November 2024 the DA is consistent with requirements under clauses 2.10, 2.11 and 2.12 of the SEPP.

As such, it is considered that the application is consistent with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

### Pittwater LEP 2014 and Pittwater 21 DCP

No other coastal related issues identified.

As such, it is considered that the application is consistent with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Natural Environment Conditions:**

**CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

**Installation and Maintenance of Sediment and Erosion Control**

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

**CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

**Stockpiling materials**

During construction, all material associated with works is to be contained at source, covered and must be within the construction area. All material is to be removed off site and disposed of according to local regulations. The property is to be kept clean and any building debris removed as frequently as required to ensure no debris enters receiving waters.

Reason: To ensure pollution control measures are effective to protect the aquatic habitats within receiving waters throughout the construction period.

**Pollution Control**

Any excess materials such as cleaning paintbrushes, lacquers, and any water from cleaning tools must not enter the stormwater network and/or receiving waterways.

Reason: To ensure that building associated chemicals and pollutants don't enter the surrounding environment.