

19 August 2020



Robert Edward Hayward , Susan Meredith Chalmers  
C/- Vaughan Milligan Development Consulting Pty Ltd PO Box 49  
NEWPORT BEACH NSW 2106

Dear Sir/Madam

**Application Number:** Mod2020/0254  
**Address:** Lot 15 DP 2170 , 12 Arthur Street, FAIRLIGHT NSW 2094  
**Proposed Development:** Modification of Development Consent DA2019/0118 granted for alterations and additions to a dwelling house

Please find attached the Notice of Determination for the above mentioned Application.

Please be advised that a copy of the Assessment Report associated with the application is available on Council's website at [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au)

Please read your Notice of Determination carefully and the assessment report in the first instance.

If you have any further questions regarding this matter please contact the undersigned on 1300 434 434 or via email quoting the application number, address and description of works to [council@northernbeaches.nsw.gov.au](mailto:council@northernbeaches.nsw.gov.au)

Regards,



Nick Keeler  
**Planner**

## NOTICE OF DETERMINATION

<b>Application Number:</b>	Mod2020/0254
<b>Determination Type:</b>	Modification of Development Consent

### APPLICATION DETAILS

<b>Applicant:</b>	Robert Edward Hayward Susan Meredith Chalmers
<b>Land to be developed (Address):</b>	Lot 15 DP 2170 , 12 Arthur Street FAIRLIGHT NSW 2094
<b>Proposed Development:</b>	Modification of Development Consent DA2019/0118 granted for alterations and additions to a dwelling house

### DETERMINATION - APPROVED

<b>Made on (Date)</b>	19/08/2020
-----------------------	------------

The request to modify the above-mentioned Development Consent has been approved as follows:

#### **A. Add Condition No. 1A - Modification of Consent - Approved Plans and supporting Documentation to read as follows:**

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

##### a) Modification Approved Plans

<b>Architectural Plans - Endorsed with Council's stamp</b>		
<b>Drawing No.</b>	<b>Dated</b>	<b>Prepared By</b>
DA.3 A	05/06/2020	Sue Connor Architects
DA.5 A	05/06/2020	Sue Connor Architects
DA.6 A	05/06/2020	Sue Connor Architects
DA.7 A	05/06/2020	Sue Connor Architects
DA.8 A	05/06/2020	Sue Connor Architects
DA.9 A	05/06/2020	Sue Connor Architects
DA.10 A	05/06/2020	Sue Connor Architects
DA.11 A	05/06/2020	Sue Connor Architects
DA.12 A	05/06/2020	Sue Connor Architects

<b>Engineering Plans</b>		
<b>Drawing No.</b>	<b>Dated</b>	<b>Prepared By</b>
Sheet-1	01/06/2020	Taylor Consulting

<b>Reports / Documentation – All recommendations and requirements contained within:</b>		
<b>Report No. / Page No. / Section No.</b>	<b>Dated</b>	<b>Prepared By</b>
BASIX Certificate No. A334477_03	04/06/2020	Sue Connor Architects

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

**B. Add Condition No. 1B - Compliance with Other Department, Authority or Service Requirements to read as follows:**

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

<b>Other Department, Authority or Service</b>	<b>EDMS Reference</b>	<b>Dated</b>
Ausgrid	Ausgrid Referral Response	20/07/2020

(NOTE: For a copy of the above referenced document/s, please see Application Tracking on Council's website [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au))

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other departments, authorities or bodies.

**C. Modify Condition No. 5 - Stormwater Disposal to read as follows:**

**Stormwater Drainage Application**

The applicant is to provide a stormwater drainage application under Section 68 of the Local Government Act 1993 to Council for approval. The submission is to include four (4) copies of Civil Engineering plans for the design of the connection to Council's pipeline which are to be generally in accordance with the civil design approved with the Development Application and Council's specification for engineering works - AUS-SPEC #1. The form can be found on Council's website at [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au) > Council Forms > Stormwater Drainage Application Form.

The fee associated with the assessment and approval of the application is to be in accordance with Council's Fees and Charges. Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and maintenance stormwater management and compliance with the BASIX requirements, arising from the development.

**D. Add Condition No. 7A - Structural Adequacy and Excavation Work to read as follows:**

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

**E. Add Condition No. 7B - Tree Protection to read as follows:**

Prior to any commencement:

- (a) Existing trees which must be retained
  - i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
  - ii) Trees located on adjoining land
  - iii) All street trees
- (b) Tree protection
  - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
  - ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
  - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
  - iv) All tree pruning within the subject site is to be in accordance with relevant local planning controls and AS 4373 Pruning of amenity trees
  - v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

**F. Add Condition No. 7C - Boundary Identification Survey to read as follows:**

A boundary identification survey, prepared by a Registered Surveyor, is to be prepared in respect of the subject site.

The plans submitted for the Construction Certificate are to accurately reflect the property boundaries as shown on the boundary identification survey, with setbacks between the property boundaries and the approved works consistent with those nominated on the Approved Plans of this consent.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of any Construction Certificate.

Reason: To ensure all approved works are constructed within the subject site and in a manner anticipated by the development consent.

**G. Add Condition No. 9A - Tree Condition to read as follows:**

During the construction period the applicant is responsible for ensuring all protected trees are

maintained in a healthy and vigorous condition. This is to be done by ensuring that all identified tree protection measures are adhered to. In this regard all protected plants on this site shall not exhibit:

- (a) A general decline in health and vigour.
- (b) Damaged, crushed or dying roots due to poor pruning techniques.
- (c) More than 10% loss or dieback of roots, branches and foliage.
- (d) Mechanical damage or bruising of bark and timber of roots, trunk and branches.
- (e) Yellowing of foliage or a thinning of the canopy untypical of its species.
- (f) An increase in the amount of deadwood not associated with normal growth.
- (g) An increase in kino or gum exudation.
- (h) Inappropriate increases in epicormic growth that may indicate that the plants are in a stressed condition.
- (i) Branch drop, torn branches and stripped bark not associated with natural climatic conditions.

Any mitigating measures and recommendations required by the Arborist are to be implemented.

The owner of the adjoining allotment of land is not liable for the cost of work carried out for the purpose of this clause.

Reason: Protection of Trees.

## Important Information

This letter should therefore be read in conjunction with DA2019/0118 dated 29/05/2019.

Please note that on site works cannot proceed unless a Construction Certificate application for the modified proposal has been lodged with and approved by Council or an accredited certifier, and relevant conditions of the Development Application have been carried out.

## Right to Review by the Council

You may request Council to review this determination of the application under Division 8.2 of the Environmental Planning & Assessment Act 1979. Any Division 8.2 Review of Determination application should be submitted to Council within 3 months of this determination, to enable the assessment and determination of the application within the 6 month timeframe.

## Right of Appeal

Section 8.10 of the Environmental Planning and Assessment Act confers on an applicant who is not satisfied with the determination of the Consent Authority a right of appeal to the Land and Environment Court within 6 months of determination.

*NOTE: A fee will apply for any request to review the determination.*

**Signed**

On behalf of the Consent Authority



Name                Nick Keeler, Planner

Date                19/08/2020