

Landscape Referral Response

Application Number:	DA2020/0346
Date:	27/05/2020
Responsible Officer:	Adam Urbancic
Land to be developed (Address):	Lot 3 DP 11547 , 62 Wakehurst Parkway NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The development application seeks approval for the construction of a new dwelling, garage and swimming pool. The proposal in terms of landscape outcome is acceptable subject to the protection of existing trees and vegetation proposed for preservation, and the completion of landscaping.

Council's Landscape Section has assessed the proposal against the following Pittwater 21 DCP Controls:

B4.22 Preservation of Trees and Bushland Vegetation

C1.1 Landscaping

D11 North Narrabeen Locality

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree Protection

A) Existing trees and vegetation shall be retained as follows:

- i) all trees and vegetation not indicated as removed, excluding exempt trees under the relevant planning instruments or legislation,
- ii) all other trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation.

B) Tree protection shall be undertaken as follows:

- i) all tree protection shall be in accordance with AS4970- 2009 Protection of Trees on Development Sites, with particular reference to Section 4 Tree Protection Measures

- ii) any tree roots exposed during excavation with a diameter greater than 25mm within the TPZ must be assessed by an Arborist. Details including photographic evidence of works undertaken shall be submitted by an AQF Level 5 Arborist to the Certifying Authority,
- iii) to minimise the impact on trees and vegetation to be retained and protected, no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- iv) no tree roots greater than 25mm diameter are to be cut from protected trees unless authorized by the Project Arborist on site,
- v) all structures are to bridge tree roots greater than 25mm diameter unless directed by a AQF Level 5 Arborist on site,
- vi) should either or both iv) and v) occur during site establishment and construction works, a AQF Level 5 Arborist shall provide recommendations for tree protection measures provided. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority.

Reason: To ensure compliance with the requirement to retain and protect significant planting on development sites.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Protection of rock and sites of significance

- a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.
- b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Required Planting

Trees shall be planted in accordance with the following schedule:

Minimum No. of Trees Required.	Species	Location	Minimum Pot Size
3	Local native trees capable of attaining a minimum height of 6 metres at maturity	Grounds of property	200mm

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Environmental and priority weed control

All weeds are to be removed and controlled in accordance with the Biodiversity Conservation Act 2016.



Reason: Preservation of environmental amenity.