

Engineering Referral Response

Application Number:	Mod2023/0567
Proposed Development:	Modification of Development Consent DA2022/0145 granted for Demolition works and construction of a mixed-use development comprising a residential flat building and shop top housing, basement parking, lot consolidation and torrens title subdivision.
Date:	16/01/2024
To:	Gareth David
Land to be developed (Address):	Lot CP SP 32072 , 812 Pittwater Road DEE WHY NSW 2099 Lot CP SP 32071 , 4 Delmar Parade DEE WHY NSW 2099

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The amended modification plans have been reviewed and are all architectural modifications which do not affect the proposed Council stormwater line realignment and upgrade works. It is noted that the ground floor plans detail the location of 2 substations within the commercial component of the building which front the road reserve adjacent to Stoney Range reserve. Councils road assets manager is to comment on the proposed location of these sub stations which front councils road reserve.

No objections subject to the proposed modification , no further conditions required.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Certification of Off Street Parking Works

The Applicant shall submit a certificate from a suitably qualified person certifying that the parking facility was constructed in accordance within this development consent and the relevant provisions of Australian/New Zealand Standard AS/NZS 2890.1:2004 parking facilities - Off-street car parking, in particular Section 2.4.5 Physical Controls and Section 2.6 Design of Domestic Driveways.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: Compliance with this consent.