

Building Assessment Referral Response

Application Number:	DA2025/0421
Proposed Development:	Strata subdivision of one lot into ten
Date:	13/05/2025
To:	Adriana Bramley
Land to be developed (Address):	Lot 1 DP 533971 , 101 Queenscliff Road QUEENSCLIFF NSW 2096

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety. The BCA Audit report submitted with the application identifies works that are required to the building. Upgrade works should be completed before the issue of the Strata Certificate.

There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

***Note:** The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.*

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

National Construction Code (BCA) Report (Class 2-9)

A 'National Construction Code (BCA) Assessment Report' / 'Fire Audit Report' from an appropriately qualified Registered Certifier* will need to be submitted with the Construction Certificate application addressing the following:

The report is to detail the extent to which the existing building (relevant affected parts) does or does not comply with the deemed-to-satisfy provisions of Sections C, D, E and F of the National Construction Code (BCA). The report is to also provide recommendations with respect to the existing building / works required to ensure that the specified measures and facilities contained in the existing building, including any modifications to be made by the proposed development are appropriate for its intended use to:

- i) restrict the spread of fire from the building to other buildings nearby, and
- ii) protect persons using the building, and to facilitate their egress from the building in the event of fire, and
- iii) where appropriate, provide access for persons with a disability, and
- iv) provide facilities and services appropriate for the development

*To be regarded as an "appropriately qualified registered certifier" the certifier must hold the relevant level of accreditation that would enable the certifier to issue a construction certificate for the subject building.

The 'National Construction Code (BCA) Assessment Report' / 'Fire Audit Report' is to be submitted to the Certifier with the Construction Certificate application.

Reason: To ensure adequate provision is made for Health, Amenity, Access & Fire Safety for building occupant health & safety.

CONDITIONS THAT MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF ANY STRATA SUBDIVISION OR SUBDIVISION CERTIFICATE

Completion of fire upgrade works

Prior to the issue of Strata Subdivision Certificate, an Occupation Certificate is to be provided to the Certifying Authority for works recommended by the National Construction Code (BCA) Assessment Report' / 'Fire Audit Report required by this consent.

Reason: To ensure compliance with the Consent issued, compliance with relevant legislation, and to ensure adequate provision is made, where required for fire safety, occupant safety, egress, access and appropriate facilities in the premises for building occupants