



NSW RURAL FIRE SERVICE

Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: DA2020/1670 (CNR-16770)
Our reference: DA20210111000063-Original-1

ATTENTION: Northern Beaches Council

Date: Friday 22 January 2021

Dear Sir/Madam,

Development Application

s4.14 - Infill - Single Dwelling - Alterations & Additions

95 Gurney Crescent Seaforth NSW 2092, 44//DP11214

I refer to your correspondence dated 08/01/2021 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

Asset Protection Zones

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

1. From the start of building works, the entire property must be managed as an inner protection area (IPA). The IPA must comprise:

- Minimal fine fuel at ground level;
- Grass mowed or grazed;
- Trees and shrubs retained as clumps or islands and do not take up more than 20% of the area;
- Trees and shrubs located far enough from buildings so that they will not ignite the building;
- Garden beds with flammable shrubs not located under trees or within 10 metres of any windows or doors;
- Minimal plant species that keep dead material or drop large quantities of ground fuel;
- Tree canopy cover not more than 15%;
- Tree canopies not located within 2 metres of the building;
- Trees separated by 2-5 metres and do not provide a continuous canopy from the hazard to the building; and,
- Lower limbs of trees removed up to a height of 2 metres above the ground.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

Construction Standards

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

2. Construction of any new Class 10b structures as defined per the National Construction Code shall be of non-combustible materials.

For any queries regarding this correspondence, please contact Marc Ellwood on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Planning and Environment Services