

Environmental Health Referral Response - acid sulfate soils

Application Number:	DA2019/1209
Responsible Officer	Kent Bull
Land to be developed (Address):	Lot 1 DP 550328 , 7 Mona Street MONA VALE NSW 2103

Reasons for referral

This application seeks consent for one or more of the following:

- All development in class 1 land
- Any works below ground surface or will lower water table in area class 2 land
- Any works beyond 1 metre or lower water table by 1 metre in class 3 land
- Any works beyond 2 metres or lower water table by 2 metres in class 4 land
- Works on land below 10 metres AHD and within 500m of class 1, 2, 3 or 4 land which are likely to lower water table below 1 metre

And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

Officer comments

General Comments

reviewed

no conditions recommended for Acid Sulphate Soils

Recommendation

APPROVAL - no conditions

Recommended Environmental Investigations Conditions:

Nil.