

## Building Assessment Referral Response

<b>Application Number:</b>	DA2019/1011
<b>To:</b>	Catriona Shirley
<b>Land to be developed (Address):</b>	Lot 2077 DP 752038 , 52 Raglan Street MANLY NSW 2095 Lot 2810 DP 726668 , 52 Raglan Street MANLY NSW 2095

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

### Recommended Building Assessment Conditions

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Building Code of Australia Upgrade requirements

The recommendations made in the Building Code Audit Report prepared by DP Property Consulting, dated 30 August 2019, Report Ref No. J3002 are to be carried out in full to the building. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

#### Building Code of Australia Access Upgrade requirements

The Building Code of Australia works and access upgrading measures to upgrade the building as detailed and recommended in the Access Report prepared by Code Performance, dated August 2019, Report Ref No. 17403 - R1.1 are to be carried out to the building. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the

Construction Certificate.

Reason: To ensure adequate provision is made for Access for building occupant safety.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Fire Safety Matters**

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of any Interim or Final Occupation Certificate.

Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.