

Natural Environment Referral Response - Coastal

Application Number:	DA2020/0234
Date:	17/03/2020
Responsible Officer	Penny Wood
Land to be developed (Address):	Lot 10 DP 1106130 , 25 - 33 Robertson Road SCOTLAND ISLAND NSW 2105

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development.

The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

As the subject site has been identified as being within the coastal zone and therefore SEPP (Coastal Management) 2018 is also applicable to the proposed development.

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps but not been included on the Coastal Vulnerability Area Map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

Comment:

As assessed in the submitted Statement of Environmental Effects (SEE) report prepared by SDG Land Development Solutions dated 23 April 2018 and Council accepts the assessment . The DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.

Pittwater LEP 2014 and Pittwater 21 DCP

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

Estuarine Risk Management

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL 2.73m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.07m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m.

However, the applicant submitted an Estuarine Risk Management Report prepared by Salients Pty. Ltd. dated 26 February 2020 proposed an Estuary Planning Level of 2.52m AHD considering design life of the boatshed as 25 years and proposed to raise the floor level of the existing boatshed from 1.35m AHD to 1.70m AHD. This has been incorporated in the design and supported in Geotechnical Assessment prepared by Ascent Geotechnical Consulting dated 13 November 2019.

Estuarine Planning Level does not apply to Jetties, Bridging Ramps or Pontoons (seaward of the foreshore). The analysis is therefore limited to the boat sheds, adjacent timber boardwalks and skids, and the seawall and beach.

Proposed development below the derived EPL

As assessed in the submitted Estuarine Risk Management Report prepared by Salients Pty. Ltd dated 26 February 2020 and Council accepts the assessment. The ground floor level for the proposed boatshed is below the derived EPL of 2.52mAHD for the site.

The proposed development is therefore subject to conditions to satisfy the relevant estuarine risk management requirements of P21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the

Responsible Officer.

Recommended Natural Environment Conditions:

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION
CERTIFICATE**

Erosion and Sediment Control Plan

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities);
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls;
- North point and scale.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.

Estuarine Hazard Design Requirements

The following applies to all development:

All development or activities must be designed and constructed such that they will not increase the level of risk from estuarine processes for any people, assets or infrastructure in surrounding properties; they will not adversely affect estuarine processes; they will not be adversely affected by estuarine processes.

To ensure Council's recommended flood evacuation strategy of 'shelter-in-place', it will need to be demonstrated that there is safe pedestrian access to a 'safe haven' above the Estuarine Planning Level.

Reason: To minimise potential hazards associated with development in an estuarine habitat.

Estuarine Planning Level Requirements

An Estuarine Planning Level (EPL) of 2.52m AHD has been justified by the client through an Estuary Risk Management Report prepared by Salients Pty. Ltd dated 26 February 2020 for the subject site and shall be applied to all development proposed below this level as follows:

- All structural elements below 2.52m AHD shall be of flood compatible materials;
- All electrical equipment, wiring, fuel lines or any other service pipes and connections must be located either above 2.52m AHD or waterproofed to this level; and

- The storage of toxic or potentially polluting goods, chemicals or materials, which may be hazardous or pollute the waterway, is not permitted below 2.52m AHD.
- All interior power supplies (including electrical fittings, outlets and switches) must be located at or above 2.52m AHD. All exterior power supplies (including electrical fittings, outlets and switches) shall be located at or above 2.52m AHD to avoid the likelihood of contact with splashing waves and spray.

Reason: To ensure aspect of the development are built at the appropriate level

Compliance with Estuarine Risk Management Report

The development is to comply with all recommendations of the approved Estuarine Risk Management Report prepared by Salients Pty. Ltd. dated 26 February 2020 and these recommendations are to be incorporated into construction plans.

Reason: To minimise potential hazards associated with development in an estuarine habitat

Structural Engineering for Estuarine Risk

Structural engineering design for the development shall be prepared, with input as necessary from a chartered professional engineer with coastal engineering as a core competency, to ensure that for its design life taken to be 25 years justified and accepted by Council, the development is able to withstand the wave impact forces and loadings identified in the approved Estuarine Risk Management Report prepared by Salients Pty. Ltd. dated 26 February 2020..

Note: The potential for component fatigue (wear and tear) should be recognised for the less severe, but more frequent, wave impact loadings.

Reason: To ensure structural engineering is prepared by an appropriately qualified professional

Engineers Certification of Plans

The structural design shall be prepared by and each plan/sheet signed by, a registered professional civil or structural engineer with chartered professional status (CP Eng) who has an appropriate level of professional indemnity insurance and shall be submitted to the Principal Certifying Authority prior to the release of the Construction Certificate.

Reason: To ensure structural engineering is prepared by an appropriately qualified professional

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Post Construction Coastal certificate

Prior to the issue of the Occupation Certificate, a Post Construction Coastal Certificate shall be submitted to the Principal Certifying Authority (Form No. 3 of the Coastline Risk Management Policy for Development in Pittwater - Appendix 6 of P21 DCP) that has been prepared and signed by a specialist coastal engineer who is a registered professional engineer with chartered professional status (CP Eng) and coastal engineering as a core competency and who has an appropriate level of professional indemnity insurance.

Reason: To ensure the development has been constructed to the engineers requirements

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

General Foreshore Matters

Unless in accordance with the approved works the Consent holder must ensure that:

- a) No materials or cleared vegetation that may obstruct flow or cause damage to the foreshore are left within the coastal foreshore area.
- b) All drainage works must not obstruct flow of water within the coastal waters. Drain discharge points are stabilised to prevent erosion. Any excavation must not result in diversion of any foreshore bank instability or damage to native vegetation.
- c) The foreshore is graded to enable the unimpeded flow of water and retaining structures result in a stable foreshore banks.
- d) Any vegetation or other material removed from the area of operations shall be disposed of lawfully. Burning of the material is not permitted.
- e) The foreshore is to function as an ecological system and as such, all works, access, roads, recreational areas, service easements and any other non-ecologically functioning work or activity are to be located beyond the foreshore other than provided by the consent.

Reason: Environmental protection, monitoring and enhancement of the foreshore.

Compliance with Estuarine Risk Management Report

The development is to comply with all recommendations of the approved Estuarine Risk Management Report prepared by Salients Pty. Ltd. dated 26 February 2020 and these recommendations are to be maintained over the life of the development.

Reason: To ensure preservation of the development and the estuarine environment