

Building Assessment Referral Response

Application Number:	DA2022/2265
Proposed Development:	Demolition works, tree removal and construction of an industrial and warehouse facility with parking and strata subdivision.
Date:	23/01/2023
To:	Thomas Prosser
Land to be developed (Address):	Lot 21 DP 881819 , 323 - 327 Warringah Road FRENCHS FOREST NSW 2086

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Building Code of Australia Fire Safety Requirements

The Building Code of Australia fire safety requirements for the building as detailed and recommended in the BCA Compliance Assessment Report prepared by Building Code Clarity, dated 15/12/2022, Job No. J1087-BCA-2, is to be considered, including any Performance Solutions, as part of the assessment for any Construction Certificate. Details demonstrating compliance are to be provided to the Certifying Authority, prior to the issue of a Construction Certificate..

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building

occupant health and safety.

Access and Facilities for Persons with Disabilities

Access and facilities to and within the building are to be provided for Persons with a Disability in accordance with the Building Code of Australia and AS1428, In this regard the Access Review Report prepared by MGAC, dated 16/12/2022, Issue A, is to be included as part of the Construction Certificate assessment. Details are to be provided to the Certifying Authority prior to the issue of the Construction Certificate and be implemented prior to occupation of the building.

Reason: To ensure adequate provision is made for access to and within the building for Persons with a disability.