

Natural Environment Referral Response - Coastal

| | |
|--|---|
| Application Number: | DA2021/1912 |
| Date: | 15/06/2022 |
| Responsible Officer | Lashta Haidari |
| Land to be developed (Address): | <p>Lot 1 DP 544341 , 2 - 4 Lakeside Crescent NORTH MANLY NSW 2100</p> <p>Lot 46 DP 12578 , 2 - 4 Lakeside Crescent NORTH MANLY NSW 2100</p> <p>Lot 47 DP 12578 , 2 - 4 Lakeside Crescent NORTH MANLY NSW 2100</p> <p>Lot 48 DP 12578 , 2 - 4 Lakeside Crescent NORTH MANLY NSW 2100</p> <p>Lot 45 DP 12578 , 8 Palm Avenue NORTH MANLY NSW 2100</p> <p>Lot 22 DP 865211 , 389 Pittwater Road NORTH MANLY NSW 2100</p> |

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application was assessed in consideration of:

- Supplied plans and reports;
- Coastal Management Act 2016;
- State Environmental Planning Policy (Resilience & Hazards) 2021 (sections 2.10, 2.11 & 2.12); and
- Relevant LEP and DCP clauses.

The application meets the requirements of the relevant Environmental Planning Instruments and policies.

The application is supported subject to conditions:

- Stormwater management (prior to construction certificate)
- Installation and maintenance of erosion and sediment controls (prior to commencement)

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater Management

Stormwater shall be disposed of in accordance with Council's Policy. The stormwater management plan is to be implemented to ensure that there is no increase in stormwater pollutant loads arising from the approved development. Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from development, ensuring that the proposed works do not negatively impact receiving waters.

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site