

Natural Environment Referral Response - Coastal

Application Number:	DA2024/0460
Proposed Development:	Demolition works and construction of shoptop housing
Date:	23/05/2024
Responsible Officer	Adam Croft
Land to be developed (Address):	Lot 188 DP 16719 , 3 Gondola Road NORTH NARRABEEN NSW 2101 Lot 187 DP 16719 , 1 Gondola Road NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This Development Application is to seek consent for construction of a shop top housing development comprising 14 residential apartments and 2 x ground floor retail (commercial) tenancies including parking for 38 vehicles over 2 levels. The application also proposes roof top communal open space and the implementation of an enhanced site landscape regime.

The application has been assessed in consideration of the *Coastal Management Act 2016*, State Environmental Planning Policy (Resilience and Hazards) 2021 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021. Hence, Clauses 2.10, 2.11 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by BBF Town Planners Pty. Ltd. dated April 2024, the DA satisfies requirements under

clauses 2.10, 2.11 and 2.12 of the SEPP R&H.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

Pittwater LEP 2014 and Pittwater 21 DCP

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

Nil.