

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2023/0072
Proposed Development:	Construction of a dwelling house
Date:	05/04/2023
To:	Jordan Howard
Land to be developed (Address):	Lot 2 DP 260241 , 100 Hilltop Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The application indicates that no works are proposed over Council's reserve adjoining the site.

No objections are raised with regard to Parks issues subject to conditions protecting Council's assets.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Works on Land Owned or Managed By Council

No works are to be carried out on land owned or managed by Council.

Note: Separate approval from Council is required for access driveways, paths, stairs, connections to underground utilities (stormwater, gas, sewer, electricity, telecommunications etc.) and landscaping works on land owned or managed by Council.

Reason: To protect the land owned or managed by Council.

Installation and Maintenance of Sediment and Erosion Control

a) Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

b) The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

c) Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all

development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

No Access Through Land Owned or Managed by Council

Site access is not approved for delivery of materials nor construction of the development through adjacent land owned or managed by Council, without the written approval of Council.

Reason: Public safety, landscape amenity and tree protection.

Storage of Materials on Land Owned or Managed by Council Prohibited

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Removal of All Temporary Structures/Materials and Construction Rubbish

Once construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences/bunds are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Reason: To protect reserve amenity and public safety.