

Directors

Sia ParsanejadBSc, MSc, Ph.D.

ret FIEAust, CPEng NPER

Ali Parsanejad.....BE,

MIEAust, CPEng NER

10 March 2024

Northern beaches council

Ms. Anne-Marie Young

pages: One (1)

issue: A

**RE: NARRABEEN LAKES PRIMARY SCHOOL –
STORMWATER MANAGMENT PLAN**

At this stage the DA architectural drawings propose the additional roof runoff to be directed to the existing site stormwater system. As the existing storm water outlets are currently catering for a similar catchment area and a preliminary review has found it viable it is believed that the proposal is workable.

In line with the BCA report requirement a stormwater management plan will be prepared during and for the Construction Certificate application.

We hope this meets with your agreement.

Please do not hesitate to contact us if you have any queries in relation to this matter.

utech engineers



Ali Parsanejad
MIEAust, CPEng NER
for & on behalf of **utech**

level 1, 1A
playfair street
the rocks 2000
australia
tel . 612 . 9884 9885
email:
utech@utech.com.au
acn . 003 242 635
abn . 21 003 242 635