

PRELIMINARY GEOTECHNICAL ASSESSMENT:

20 Hurdis Avenue, Frenchs Forest

1.0	<i>LANDSLIP RISK CLASS (Highlight indicates Landslip Risk Class of property)</i>
<input checked="" type="checkbox"/>	<i>A - Geotechnical Report not normally required</i>
<input checked="" type="checkbox"/>	<i>B - Geotechnical Engineer (Under Council Guidelines) to decide if Geotechnical Report is required</i>
<input type="checkbox"/>	<i>C - Geotechnical Report is required</i>
<input type="checkbox"/>	<i>D - Geotechnical Engineer (Under Council Guidelines) to decide if Geotechnical Report is required</i>
<input type="checkbox"/>	<i>E - Geotechnical Report required</i>

2.0 Proposed Development

- 2.1 Construct a new deck on the downhill side of the house.
- 2.2 Various other internal and external alterations.
- 2.3 Apart from those for footings, no excavations are required. No fills are shown on the plans.
- 2.4 Details of the proposed development are shown on 4 drawings prepared by Connect Drafting, drawing numbered CD-158/20, sheets 1 to 4, Issue A, dated 3/7/2020.

3.0 Site Location

- 3.1 The site was inspected on the 29th June, 2020.
- 3.2 This residential property is on the low side of the road and has a NW aspect. The block is located on the gently graded upper reaches of a hillslope. No rock outcrops on the property. The Sydney 1:100 000 Geological sheet indicates the site is underlain by a shale band within the Hawkesbury Sandstone that is described as a

medium to coarse grained quartz sandstone with very minor shale and laminite lenses. The bedrock is expected to underlie the surface at relatively shallow depths. The natural surface of the block has been altered little with the development to date. The proposed development will not alter the surface further for the proposed works.

3.3 The site shows no indications of historical movement in the natural surface that could have occurred since the property was developed. We are aware of no history of instability on the property.

4.0 Site Description

From the road frontage to the lower common boundary, the slope falls at angles of <5°. At the road frontage, a bitumen driveway runs to two garages on the lower ground floor of the house. Between the road frontage and the house is a gently sloping lawn. The part two-storey brick house is supported on brick walls and brick piers. The external supporting brick walls of the house display no significant signs of movement and the supporting brick piers stand vertical. Another gently sloping lawn falls from the downhill side of the house to the lower boundary. The area surrounding the house and driveway is mostly lawn covered with some paved areas. No signs of movement associated with slope instability were observed on the grounds. No cliffs or large rock faces were observed on the property or in the near vicinity. The adjoining neighbouring properties were observed to be in good order as seen from the road and the subject property.

5.0 Recommendations

The proposed development and site conditions were considered and applied to the Council Flow Chart.


Provided good engineering and building practice are followed, no further Geotechnical assessment is recommended for the proposed development.

White Geotechnical Group Pty Ltd.



Ben White M.Sc. Geol.,
AusIMM., CP GEOL.
No. 222757
Engineering Geologist.

Preliminary Assessment Flow Chart – Northern Beaches Council (Warringah)



Information about your Preliminary Assessment

This Preliminary Assessment relies on visual observations of the surface features observed during the site inspection. Where reference is made to subsurface features (e.g. the depth to rock) these are interpretations based on the surface features present and previous experience in the area. No ground testing was conducted as part of this assessment and it is possible subsurface conditions will vary from those interpreted in the assessment.

In some cases, we will recommend no further geotechnical assessment is necessary despite the presence of existing fill or a rock face on the property that exceed the heights that would normally trigger a full geotechnical report, according to the Preliminary Assessment Flow Chart. Where this is the case, if it is an existing fill, it is either supported by a retaining wall that we consider stable, or is battered at a stable angle and situated in a suitable position on the slope. If it is a rock face that exceeds the flow chart limit height, the face has been deemed to be competent rock that is considered stable. These judgements are backed by the inspection of over 5000 properties on Geotechnical related matters.

The proposed excavation heights referred to in section 2.0 of this assessment are estimated by review of the plans we have been given for the job. Although we make every reasonable effort to provide accurate information excavation heights should be checked by the owner or person lodging the DA. If the excavation heights referred to in in section 2.0 of this assessment are incorrect we are to be informed immediately and before this assessment is lodged with the DA.