

EAVES GUTTER SPECIFICATION:

EAVES GUTTER GRADIENTS TO BE 1:500 OR GREATER.

EAVES GUTTER TO HAVE AN EFFECTIVE CROSS SECTIONAL AREA AS PER TABLE ABOVE.

DOWNPIPES CROSS-SECTION TO BE AS PER TABLE ABOVE.

FASCIA TO BE A MINIMUM OF 14mm ABOVE GUTTER OVERTFLOW.

UNDERGROUND SERVICES
DIAL 1100 BEFORE YOU DIG FOR LOCATION OF UNDERGROUND SERVICES PRIOR TO ANY CONSTRUCTION WORKS.
CONTACT TELSTRA FOR WRITTEN PERMISSION TO MAINTAIN OR RELOCATE ANY EXISTING SERVICE PIT.
ALL SERVICES ARE TO MATCH INTO THE NEW FOOTPATH LEVELS
CONTACT THE RELEVANT AUTHORITY FOR ADJUSTMENT TO SERVICES.


EXISTING STORMWATER SYSTEM TO BE CHECKED AND
UPGRADED AS REQUIRED

LEAF GUARD
TO BE INSTALLED TO EACH DOWN PIPE OR ALTERNATIVELY
GUTTER GUARD CAN BE USED

ALL PIPES INCL. DOWN PIPES SHALL BE SEWER GRADE
uPVC WITH SOLVENT WELDED JOINTS (U.N.O.).

WHERE WORKS ARE UNDERTAKEN ON PUBLIC ROADS, ADEQUATE TRAFFIC CONTROL AND DIRECTIONS TO MOTORISTS SHALL BE PROVIDED.

RAINWATER TANKS AND ASSOCIATED PLUMBING WORKS TO BE INSTALLED AND CONFIGURED BY A LICENSED PLUMBER. PUMP TO BE INSTALLED BY A LICENSED ELECTRICIAN.



1:20