

Natural Environment Referral Response - Flood

Application Number:	DA2021/1742
Date:	10/10/2021
To:	Catriona Shirley
Land to be developed (Address):	Lot 1 DP 959013 , 24 Lauderdale Avenue FAIRLIGHT NSW 2094

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed DA involves a new swimming pool and internal works. These works are outside the 1% AEP flood extent and generally meets the flood controls in the LEP and DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

Nil.