Sent:	30/03/2020 4:29:09 PM
Subject:	NSW RFS Determination - Your Reference - DA2020/0080 (CNR-4867)
Attachments:	DA20200221000668-Original-1 - 29-03-2020 08_26_07 - Determination Letter.pdf;



Attention: Kylie Bridge

Your Reference: DA2020/0080 (CNR-4867)

Application Details: s4.14 – Other – Original

Site Address: 13 Minkara Road Bayview NSW 2104

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Alastair Patton on 1300 NSW RFS and quote DA20200221000668-Original-1.



**Planning and Environment Services** 

# **NSW RURAL FIRE SERVICE**

Locked Bag 17 Granville NSW 2142

P 1300 NSW RFS E records@rfs.nsw.gov.au

www.rfs.nsw.gov.au | www.facebook.com/nswrfs | www.twitter.com/nswrfs

PREPARE. ACT. SURVIVE.



Northern Beaches Council PO Box 882 MONA VALE NSW 1660

Your reference: DA2020/0080 (CNR-4867)
Our reference: DA20200221000668-Original-1

ATTENTION: Kylie Bridge Date: Monday 30 March 2020

Dear Sir/Madam,

Development Application s4.14 - Other - Single Dwelling - Alterations & Additions 13 Minkara Road Bayview NSW 2104, 8//DP238742

I refer to your correspondence dated 17/02/2020 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act* 1979.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

#### **Asset Protection Zones**

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

### [APZ 1.0]

From the start of building works, the entire property must be managed as an inner protection area (IPA). The IPA must comprise:

- Minimal fine fuel at ground level;
- Grass mowed or grazed;
- Trees and shrubs retained as clumps or islands and do not take up more than 20% of the area;
- Trees and shrubs located far enough from buildings so that they will not ignite the building;
- Garden beds with flammable shrubs not located under trees or within 10 metres of any windows or doors:
- Minimal plant species that keep dead material or drop large quantities of ground fuel;
- Tree canopy cover not more than 15%;
- Tree canopies not located within 2 metres of the building;
- Trees separated by 2-5 metres and do not provide a continuous canopy from the hazard to the building; and.

1

• Lower limbs of trees removed up to a height of 2 metres above the ground.

# **Construction Standards**

# [D&C 1.0]

The proposed awning associated with the existing dwelling must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2009 Construction of buildings in bush fire-prone areas or NASH Standard (1.7.14 updated) 'National Standard Steel Framed Construction in Bushfire Areas – 2014' as appropriate and section A3.7 Addendum Appendix 3 of Planning for Bush Fire Protection 2006.

For any queries regarding this correspondence, please contact Alastair Patton on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Planning and Environment Services