page 1/7

BASIX[™]Certificate

Building Sustainability Index www.planningportal.nsw.gov.au/development-and-assessment/basix

Alterations and Additions

Certificate number: A1791335

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Definitions" dated 10/09/2020 published by the Department. This document is available at www.planningportal.nsw.gov.au/definitions

Secretary

Date of issue: Thursday, 10 April 2025 To be valid, this certificate must be lodged within 3 months of the date of issue.



| Project name | 17 Argyle St | | | | | |
|--|---|--|--|--|--|--|
| Street address | 17 ARGYLE Street BILGOLA PLATEAU 2107 | | | | | |
| Local Government Area | Northern Beaches Council | | | | | |
| Plan type and number | Deposited Plan DP16327 | | | | | |
| Lot number | 279 | | | | | |
| Section number | - | | | | | |
| Project type | | | | | | |
| Dwelling type | Dwelling house (detached) | | | | | |
| Type of alteration and addition | ion and addition The estimated development cost for my renovation work is \$50,000 or more, and doe not include a pool (and/or spa). | | | | | |
| N/A | N/A | | | | | |
| Certificate Prepared by (plea | ase complete before submitting to Council or PCA) | | | | | |
| Name / Company Name: Bodill Ventures Pty Ltd | | | | | | |

| Fixtures and systems | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------|--------------------|
| Lighting | | | |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light- emitting-diode (LED) lamps. | | ~ | ~ |
| Fixtures | | | • • |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. | | ~ | ~ |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating. | | ~ | ~ |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating. | | ~ | |

| Construction | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check | | |
|---|--|---|--------------------|--|--|
| Insulation requirements | | | | | |
| The applicant must construct the new or alte listed in the table below, except that a) addit insulation specified is not required for parts | ~ | ~ | ~ | | |
| Construction | Additional insulation required (R- value) | Other specifications | | | |
| floor above existing dwelling or building. | nil | N/A | | | |
| external wall: framed (weatherboard, fibro, metal clad) | R1.30 (or R1.70 including construction) | | | | |
| raked ceiling, pitched/skillion roof: framed | ceiling: R1.74 (up), roof: foil backed blanket (55 mm) | medium (solar absorptance 0.475 - 0.70) | | | |
| flat ceiling, flat roof: structural panel >125 mm | ceiling: nil (up), roof: 50 mm foil backed polystyrene board | medium (solar absorptance 0.475 - 0.70) | | | |

| Glazing requirements | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check | |
|--|---------------------|---------------------------------|--------------------|--|
| Windows and glazed doors | | | | |
| The applicant must install the windows, glazed doors and shading devices, in accordance with the specifications listed in the table below. Relevant overshadowing specifications must be satisfied for each window and glazed door. | ~ | ~ | ~ | |
| The following requirements must also be satisfied in relation to each window and glazed door: | | ~ | ~ | |
| Each window or glazed door with improved frames, or pyrolytic low-e glass, or clear/air gap/clear glazing, or toned/air gap/clear glazing must have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. The description is provided for information only. Alternative systems with complying U-value and SHGC may be substituted. | | ~ | ~ | |
| For projections described in millimetres, the leading edge of each eave, pergola, verandah, balcony or awning must be no more than 500 mm above the head of the window or glazed door and no more than 2400 mm above the sill. | ~ | ~ | ~ | |
| Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35. | | ~ | ~ | |
| Pergolas with fixed battens must have battens parallel to the window or glazed door above which they are situated, unless the pergola also shades a perpendicular window. The spacing between battens must not be more than 50 mm. | | ~ | ~ | |

| Glazing requir | ements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|-----------------------|---|--|-----------------------------|-------------------------------|---|---|---------------------|---------------------------------|--------------------|
| Windows and gla | Vindows and glazed doors glazing requirements | | | | | | | | |
| Window/door number | Orientation | Area of glass including frame (m2) | Overshadowing height (m) | Overshadowing distance (m) | Shading device | Frame and glass type | | | |
| W1 | N | 1.32 | 0 | 0 | eave/ verandah/ pergola/balcony >=600 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W2 | E | 2.1 | 0 | 0 | eave/ verandah/ pergola/balcony >=450 mm | improved aluminium, single pyrolytic low-e, (U- value: 4.48, SHGC: 0.46) | | | |
| W3 | S | 1.2 | 0 | 0 | eave/ verandah/ pergola/balcony >=600 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W4 | E | 0.75 | 0 | 0 | eave/ verandah/ pergola/balcony >=450 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W5 | W | 4.5 | 0 | 0 | eave/ verandah/ pergola/balcony >=750 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |

| Glazing requirements | | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|-----------------------|-------------|--|-----------------------------|-------------------------------|---|---|---------------------|---------------------------------|--------------------|
| Window/door number | Orientation | Area of glass including frame (m2) | Overshadowing height (m) | Overshadowing distance (m) | Shading device | Frame and glass type | | | |
| W6 | N | 0.96 | 0 | 0 | eave/ verandah/ pergola/balcony >=600 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W7 | N | 1.26 | 0 | 0 | eave/ verandah/ pergola/balcony >=600 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| W8 | W | 0.86 | 0 | 0 | eave/ verandah/ pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a V in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a V in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a V in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.