

Engineering Referral Response

Application Number:	DA2019/0087
To:	
Land to be developed (Address):	Lot 5 DP 25713 , 8 Gladys Avenue FRENCHS FOREST NSW 2086

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

Application rejected on 13/02/19. No assessment undertaken.

Referral Body Recommendation

No answer provided

Refusal comments

Recommended Engineering Conditions:

Nil.