

Environmental Health Referral Response - commercial use

| | |
|--|--|
| Application Number: | DA2020/0021 |
| To: | Lashta Haidari |
| Land to be developed (Address): | Lot 11 DP 1193189 , Pittwater Road COLLAROY NSW 2097 |

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments General Comments

Proposal to demolish Long Reef Surf Life Saving Club and construct a new structure. Environmental Health have assessed the matter of the café to be constructed.

Standard conditions regarding licensing and construction of café to relevant Australian Standards and regulations.

Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

Registration of food business

The food business must be registered with the Appropriate Regulatory Authority.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from a suitably qualified person that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements.

Mechanical Ventilation certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from the installer of the mechanical ventilation system that the design, construction and installation of the mechanical ventilation system is compliant with the requirements of AS1668 The use of mechanical ventilation.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the mechanical ventilation system complies with the design requirements.