

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2021/0931
Date:	13/10/2021
To:	Gareth David
Land to be developed (Address):	Lot 5 DP 253614 , 264 Hudson Parade CLAREVILLE NSW 2107

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The plans indicate that no new works are proposed over the adjoining Council Reserve, however, the works within the site have the potential to affect council land, vegetation and the waterway.

Conditions have been included to ensure protection of Council assets adjoining the site.

No objections are raised to approval subject with regard to Parks issues subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Works on Land Owned or Managed By Council

No works are to be carried out on land owned or managed by Council.

Note: Separate approval from Council is required for access driveways, paths, stairs, connections to underground utilities (stormwater, gas, sewer, electricity, telecommunications etc.) and landscaping works on land owned or managed by Council.

Reason: To protect the land owned or managed by Council.

Installation and Maintenance of Sediment and Erosion Control

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

Dilapidation Report of Land Owned or Managed by Council

A Pre-Construction Dilapidation Report shall contain a survey of pre-existing land features including photographic record of the land under Council's care control and management adjoining the development, detailing the physical condition of items such as, but not exclusively limited to, physical assets such as crossovers, driveways, footpaths, utilities, furniture, play equipment, trees, gardens, lawn areas, bushland and any rock outcrops.

This Pre-Construction Dilapidation Report shall be submitted to Council and the Certifying Authority prior to commencement of works.

Any damage to these assets during the works must be replaced like for like to the satisfaction of Council and the Certifying Authority.

The applicant may be held liable to any damage to public infrastructures in the vicinity of the site, where such damage is not accurately recorded under the requirements of this condition. In this regard, where required, the damage deposit lodged by the applicant may be used by Council to repair such damage on Council's property.

Reason: Protection of Council's assets.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Storage of Materials on Land Owned or Managed by Council Prohibited

The dumping or storage of building materials, spoil, vegetation, green waste or any other material in land owned or managed by Council is prohibited.

Reason: Public safety and environmental protection.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Removal of All Temporary Structures/Materials and Construction Rubbish

Once construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences/bunds are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate.

Reason: To protect reserve amenity and public safety.