

## Parks, Reserves and Foreshores Referral Response

Application Number:	DA2020/1289
Date:	22/01/2021
To:	Anne-Marie Young
Land to be developed (Address):	Lot 9 DP 15762 , 11 Bruce Street MONA VALE NSW 2103

### Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore  
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

### Officer comments

The development application is for the construction of a new dwelling, swimming pool and associated landscape works.

Council's Parks Referral is assessed against the following Pittwater 21 DCP Controls:

- B8.2 Construction and Demolition - Erosion and Sediment Management

The site adjoins a Public Reserve known as Warriewood Beach Reserve that is located downslope of the development site. During the works surface sediment runoff and/or erosion is to be controlled, managed and contained to the immediate downslope of the works area and obstruct from entering the public reserve downslope.

No encroachments are permitted upon public land and all works shall be confined within the legal boundaries.

Subject to this requirement to satisfy clause B8.2, Parks Referral has no objections to the proposal, with conditions of consent.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Parks, Reserves and Foreshores Conditions:

#### CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

##### Installation and Maintenance of Sediment and Erosion Control

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area, in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period.

Techniques used for erosion and sediment control on site are to be adequately maintained and

monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: to protect the surrounding environment from the effects of sedimentation and erosion from the site.

#### **Works on Land owned or managed by Council**

No works are to be carried out on Land owned or managed by Council.

Note: Separate approval from Council is required for access driveways, paths, stairs, connections to underground utilities (stormwater, gas, sewer, electricity, telecommunications etc.), and landscaping works on Land owned or managed by Council.

### **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

#### **No Access through Land owned or managed by Council**

Site access is not approved for delivery of materials nor construction of the development through adjacent Land owned or managed by Council, without the written approval of Council.

Reason: public safety, landscape amenity and vegetation protection.

#### **Protection of Council's Public Assets**

Any damage to Council's public assets shall be made good by the applicant and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

The dumping or storage of building materials, spoil, vegetation, green waste, or any other material in Land owned or managed by Council is prohibited.

Existing trees shall be protected in accordance with AS4970-2009 Protection of Trees on Development Sites, with particular reference to Section 4, with no ground intrusion into the tree protection zone and no trunk, branch nor canopy disturbance. Should any problems arise with regard to the existing trees on public land during the construction period, the applicant is to immediately Contact Council's Tree Services section and resolve the matter to Council's satisfaction.

Reason: to protect and/or restore any damaged public asset.