

## Landscape Referral Response

<b>Application Number:</b>	DA2019/0335
<b>Date:</b>	13/06/2019
<b>Responsible Officer:</b>	Jordan Davies
<b>Land to be developed (Address):</b>	Lot 31 DP 33000 , 84 Hilma Street COLLAROY PLATEAU NSW 2097

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

The Arborists report submitted with the application is noted. The report indicates that a mature *Syzigium australe* is required to be removed to accommodate the proposed works.

Based on the plans provided the rear extension and new pool will significantly impact upon the tree protection zone of this tree, requiring removal of a significant amount of roots and canopy of the tree. As such the tree is unable to be retained.

Conditions for replanting have been included if the works are to be approved.

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Refusal comments

### Recommended Landscape Conditions:

#### **CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT**

#### Tree protection

- (a) Existing trees which must be retained
- i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
  - ii) Trees located on adjoining land

- (b) Tree protection

- i) No tree roots greater than 30mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
- ii) All structures are to bridge tree roots greater than 30mm diameter unless directed otherwise by a qualified Arborist on site.
- iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

**Required Planting**

Trees shall be planted in accordance with the following schedule:

No. of Trees Required.	Species	Location	Minimum Pot Size
1	Local native tree species capable of attaining a minimum height of 4 metres at maturity	1 x Rear Yard	25 Litre

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.