

Waste Referral Response

Application Number:	DA2021/2257
Date:	14/01/2022
To:	Maxwell Duncan
Land to be developed (Address):	Lot 100 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 101 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 102 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 1 DP 1034722 , 42 North Steyne MANLY NSW 2095

Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

Officer comments

Waste Management Assessment

Proposal is approved with conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Waste Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Waste and Recycling Requirements

Details demonstrating compliance with Northern Beaches Waste Management Guidelines, are to be submitted to and approved by the Certifying Authority prior to the issue of any Construction Certificate.

Note: If the proposal, when compliant with the Northern Beaches Waste Management Guidelines, causes inconsistencies with other parts of the approval i.e. architectural or landscaped plans, a modification(s) to the development may be required.

Reason: To ensure adequate and appropriate waste and recycling facilities are provided.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Waste/Recycling Requirements (Waste Plan Submitted)

During demolition and/or construction the proposal/works shall be generally consistent with the submitted Waste Management Plan dated October 2021.

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided.

Waste/Recycling Requirements (Materials)

During demolition and/or construction the following materials are to be separated for recycling: timber, bricks, tiles, plasterboard, metal, concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Garbage and Recycling Facilities

All internal walls of the waste rooms shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate cleaning.

Waste room floors shall be graded and drained to an approved Sydney Water drainage system.

Waste rooms shall be clear of any other services or utilities infrastructure such as gas, electricity air-conditioning, plumbing, piping ducting or equipment.

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.

Waste and Recycling Facilities Certificate of Compliance

The proposal shall be constructed in accordance with the Northern Beaches Waste Management Guidelines.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste and recycling facilities are provided.

Waste/Recycling Compliance Documentation

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste is minimised and recycled.

Positive Covenant for Council and Contractor Indemnity

A positive covenant shall be created on the title of the land prior to the issue of an Interim/Final Occupation Certificate requiring the proprietor of the land to provide access to the waste storage facilities. The terms of the positive covenant are to be prepared to Council's requirements, (Appendix E of the Waste Management Guidelines), at the applicant's expense and endorsed by Council prior to lodgement with NSW Land Registry Services. Northern Beaches Council shall be nominated as the

party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities.

Authorisation of Legal Documentation Required for Waste Services

The original completed request form (NSW Land Registry Services form 13PC) must be submitted to Council for authorisation prior to the issue of the Interim/Final Occupation Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. Where required by Council or the Certifying Authority, a Compliance Certificate shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Access to the Residential Bin Storage Room

There must be unrestricted access from Henrietta Lane to the residential waste storage room on collection day.

- The roller door to the Henrietta Lane must be in an open position from 5am to 6pm on collection day. Alternatively a press button to open the roller door that will remain open for 20 minutes is acceptable.
- The applicant must demonstrate that there is:
 - 1.2m clearance in the commercial garbage/ loading area outside the residential bin storage room door.
 - Clear pedestrian access way between Henrietta Lane and the Residential Bin Storage Room through the commercial garbage/store/BOH for service staff on collection day. Vehicles, commercial bins and other infrastructure must not block access.
- The door to the residential bin room must remain unlocked on the nominated collection day - and be able to be latched in the open position. The service door to the residential bin room should be a roller door to allow unobstructed access to the bins.
- The residential bin room doors are to remain locked at all other times with only residents having key access. Commercial operators are not to have access to the residential bin storage room.

Reason: To ensure ongoing access for servicing of residential bins.

Servicing of Residential and Commercial Bins

- The owners corporation / building occupants are not to place bins outside the building for collection.
- Council will provide a "wheel out / wheel in service" for the residential waste & recycle bins at this property from Henrietta Lane.

- The plan of management for the building will need to include that the proprietors of the commercial premises must arrange a “wheel out / wheel in service” for the commercial waste & recycling bins at this property from Henrietta Lane.

Reason: To maintain the streetscape and public amenity of the area.

Commercial Waste and Recycling Storage

Commercial waste and recycling material/storage bins must be stored in a separate area to the residential waste and recycling material/storage bins as shown on the approved plans.

Reason: To ensure that commercial waste and residential waste is not mixed and is properly managed.