

---

**Sent:** 30/11/2016 8:36:13 AM  
**Subject:** Re: MOD2016/0307 - 896 Pittwater Rd Dee Why  
**Attachments:** 20161130 Augrid Submission 896 Pittwater Rd Dee Why.pdf;

Hi,

Here is Ausgrid's submission. The original has also been posted

Regards,

**Clinton Gee | Engineer | Planning & Supply Negotiations - Northern Beaches | AUSGRID**

Level GRD FLR, BLDG 2, Dymrna Street Cnr Middleton Road Dee Why NSW 2099 AUSTRALIA  
☎: 02 8569 6352 (Extn 66352) | 📠: 02 9981 9918 (Extn 39918) | ✉: [CGee@ausgrid.com.au](mailto:CGee@ausgrid.com.au) |

Please consider the environment before printing this email

To,

cc

24/11/2016 09:58 AM

SubjectMOD2016/0307 - 896 Pittwater Rd Dee Why

24 November 2016

Dear Sir/Madam

**Request for Comments on Application for AUSGRID - SEPP - Infrastructure 2007**

**Development Application No. Mod2016/0307**

**Description: Modification of Development Consent DA2015 granted for Drainage and Stormwater Management works and Installation of shoring walls and bulk excavation**

**Address: 9, 11, 15 & 17 Howard Avenue and 14, 16 & 28 Oaks Avenue and 884, 888, 890, 892, 894 & 896 Pittwater Road DEE WHY**

Council requires referral comments on the above application.

To access the documentation please go to:

<https://eservices1.warringah.nsw.gov.au/ePlanning/live/Public/XC.Track/SearchApplication.aspx?id=814371>

You can open each document by selecting the documents tab and clicking on the title or the icon next to it. You can download these by saving the files to your computer. If you experience any difficulty try right-clicking and selecting 'save link as' for each document.

Your referral response comments would be greatly appreciated within 21 days of the date of this letter.

Enquiries regarding this Development Application may be made to Lashta Haidari on 9942 2111 Monday to Friday between 8.30am to 5.00pm or anytime at [council@northernbeaches.nsw.gov.au](mailto:council@northernbeaches.nsw.gov.au).

Yours faithfully,

John Slater

Development Assessment Liaison Officer

This e-mail may contain confidential or privileged information.

If you have received it in error, please notify the sender immediately via return e-mail and then delete the original e-mail.

If you are the intended recipient, please note the change of sender email address to @ausgrid.com.au.

Ausgrid has collected your business contact details for dealing with you in your business capacity. More information about how we handle your personal information, including your right of access is contained at <http://www.ausgrid.com.au/>

Northern Beaches Council

PLEASE CONSIDER THE ENVIRONMENT BEFORE PRINTING THIS EMAIL. This email and any materials contained or attached to it ("Contents") may contain confidential information. If you are not the intended recipient contact the sender immediately, delete the communication from your system and destroy any copies. The contents may also be subject to copyright. Any unauthorised copying, disclosure or distribution of the contents is strictly prohibited. Any views expressed in the contents are those of the individual sender, except where the sender specifically states them to be the views of Northern Beaches Council. Northern Beaches Council makes no implied or express warranty that the integrity of this communication has been maintained. The contents may contain errors, computer viruses or have been subject to interference in transmission. Northern Beaches Council. [Northern Beaches Council](#)



Telephone: 02 8569 6352  
Reference: TRIM 2013/31  
30 November 2016

570 George Street  
Sydney NSW 2000  
Telephone 13 1525  
+61 13 1525  
Facsimile (02) 9269 2830  
[www.ausgrid.com.au](http://www.ausgrid.com.au)

Address all mail to  
Local Address:  
51-59 Bridge Road  
Hornsby NSW 2077

John Slater  
Development Assessment Liaison Officer  
Northern Beaches Council Warringah  
725 Pittwater Road  
Dee Why NSW 2099

Dear John Slater,

Your Ref: Mod2016/0307

**Re: Development Application No. Mod2016/0307  
9, 11, 15 & 17 Howard Avenue and 14, 16 & 28 Oaks Avenue and 884, 888, 890,  
892, 894 & 896 Pittwater Road DEE WHY**

I refer to your email dated 24 November 2016, concerning the above development. This letter is Ausgrid's (formally EnergyAustralia ) response under clause 45(2) of *State Environmental Planning Policy (Infrastructure) 2007*.

Based on the information provided in your correspondence the proposed development will comply with statutory clearances from Ausgrid's electrical mains and accordingly there is no objection to this development.

Please note there are Ausgrid assets in the vicinity which are highly susceptible to finished levels. Altering ground levels can affect the safe operation of these assets. In this area in particular the following assets are likely to be affected: kiosk substations, cables including high density polyethylene (HDPE) cables, conduits, pillars, pits and poles.

Altering the finished levels may require the relocation of Ausgrid assets. Relocation of assets is considered contestable works. All Ausgrid assets that are affected by the proposal are required to be relocated. In this event the applicant is to contact our Contestability Group on 8569 6727 or [contestability@ausgrid.com.au](mailto:contestability@ausgrid.com.au) to proceed with a network asset relocation project.

All works near Ausgrid assets are to comply with Ausgrid's Network Standards, in particular:

- Works near kiosk substations need to comply with NS141 Site Selection and Construction Design Requirements for Kiosk Substations. Please note, Ausgrid requires unrestricted access 24 hours per day, 7 days per week. All substation doors must be fully operable and accessible at all times for the duration of the proposed works and are not to be blocked by construction fencing / hoarding, construction materials or any other associated items.  
Also, works near substations are to comply with:
  - Reference Levels and the precautionary requirements of the draft ARPANSA's Radiation Protection Standard for Exposure Limits to Electric and Magnetic Fields 0 Hz - 3 kHz, 7 December 2006  
<http://www.arpansa.gov.au/RadiationProtection/Basics/elf.cfm>
  - Energy Network Association's Substation Earthing Guide, ENA EGI-2006 to address hazardous step, touch and transfer voltages do not exist during fault conditions (50Hz or transient).  
<http://www.saiglobal.com/shop/script/search.asp>
- Works near cables and conduits are to comply with NS156 Working Near or Around Underground Cables
- Works near HDPE cables and pits are to comply with NUS199 Safe Electrical Working on Low Voltage Assets
- Works near asbestos assets including asbestos pits are to comply with NS211 Working with Asbestos Products
- Works near poles are to comply with NS146 Safety Inspection Procedure for Working on Poles and NS156 Working Near or Around Underground Cables

In the event the safety of Ausgrid assets are compromised, Ausgrid will be forced to rectify these issues at the applicant's cost.

As you would be aware, the assessment and evaluation of environmental impacts for a new development that requires development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the *Environmental Planning and Assessment Act 1979*. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid require that due consideration be given to the compatibility of proposed developments with existing Ausgrid's infrastructure, particularly in relation to risks of electrocution, fire risks, Electric and Magnetic Fields (EMFs), Noise, Visual Amenity and other matters that may impact on Ausgrid or the development.

It should be noted that trying to mitigate such impacts for established developments can be very expensive and is often limited by design factors. For this reason, the most cost-effective option is usually modification of the proposed development early in the assessment process. Such measures

could include appropriate buffer distances, screening structures, building design, orientation and construction.

Where Council considers that the site of the development is suitable and the development comprises or involves a type listed in Table 1, then Ausgrid require the following development consent conditions to be imposed to ensure the safety and compatibility of both the development and Ausgrid's assets.

Please contact Ausgrid's Grant Greene-Smith if you would like further assistance in this matter on (02) 9269 2169.

Yours faithfully

A handwritten signature in dark ink, appearing to be 'CG' or similar, written in a cursive style.

Clinton Gee  
Engineer  
Ausgrid

**Table 1 – Required Conditions of Approval**

<b>Development comprising or involving any of the following</b>	<b>Conditions of approval</b>
Clause 45 (a) the penetration of ground within 2m of an underground electricity power line.	<b>Condition b)</b>
Clause 45 (a) the penetration of ground within 2m of an electricity distribution pole or within 10m of any part of an electricity tower.	<b>Condition a)</b>
Clause 45 b (i) within an easement for electricity purposes (whether or not the electricity infrastructure exists).	<b>Conditions a) and e)</b>
Clause 45 b (i) immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).	<b>Conditions a), and d)</b>
Clause 45 b (ii) immediately adjacent to an electricity substation.	<b>Conditions a), d) and f)</b>
Clause 45 b (iii) within 5m of an exposed overhead electricity power line.	<b>Conditions a) and d)</b>
Clause 45 (c) installation of a swimming pool any part of which is: (i) within 30m of a structure supporting an overhead electricity transmission line, measured horizontally from the top of the pool to the bottom of the structure at ground level, or (ii) within 5m of an overhead electricity power line, measured vertically upwards from the top of the pool.	<b>Condition a)</b>
Clause 45 (d) development involving or requiring the placement of power lines underground, unless an agreement with respect to the placement underground of power lines is in force between the electricity supply authority and the council for the land concerned.	<b>Condition a)</b>
Any of the above development that involves the planting of vegetation adjacent to electricity infrastructure.	<b>Condition e)</b>

### **Development Consent Conditions**

**Condition a)** Prior to any development being carried out, the approved plans must be submitted to Ausgrid's local customer service office for approval to determine whether the development will affect Ausgrid's network or easements<sup>1</sup>.

**Condition b)** The applicant must check the location of underground cables by using *Dial Before You Dig*<sup>2</sup> and comply with the requirements of Ausgrid's *NS 156 - Working Near or Around Underground Cables*<sup>3</sup>.

**Condition c)** Prior to the issue of a Construction Certificate (or an Occupation Certificate where a Construction Certificate is not required), the applicant must provide to the Council and Ausgrid a noise assessment report. The report must address, in relation to the adjacent substation, the requirements of the amenity or intrusive criteria in section 2.4 of the EPA's *NSW Industrial Noise Policy, 2000*<sup>4</sup>.

**Condition d)** The development must comply with both the Reference Levels and the precautionary requirements of the draft ARPANSA's *Radiation Protection Standard for Exposure Limits to Electric and Magnetic Fields 0 Hz - 3 kHz, 7 December 2006*<sup>5</sup>

**Condition e)** The development must comply with Ausgrid's *Tree Safety Management Plan*<sup>6</sup>.

**Condition f)** The development must be carried out in accordance with the *Energy Network Association's Substation Earthing Guide, ENA EGI-2006*<sup>7</sup> so that hazardous step, touch and transfer voltages do not exist during fault conditions (50Hz or transient).

---

<sup>1</sup> <http://www.ausgrid.com.au/Common/Safety.aspx>

<sup>2</sup> <http://www.ausgrid.com.au/Common/Safety/Electrical-Safety/Dial-Before-You-Dig.aspx#.V-iirfmqpBc>

<sup>3</sup> <http://www.ausgrid.com.au/Common/Industry/Network-documentation/Network-standards.aspx>

<sup>4</sup> <http://www.epa.nsw.gov.au/noise/applicnotesindustnoise.htm>

<sup>5</sup> <http://www.arpansa.gov.au/RadiationProtection/Basics/elf.cfm>

<sup>6</sup> <https://www.ausgrid.com.au/~media/Files/Network/Regulations%20and%20Reports/Tree%20Safety%20Management%20Plan%20February%202015.pdf>

<sup>7</sup> <http://www.saiglobal.com/shop/script/search.asp>