

Natural Environment Referral Response - Coastal

Application Number:	Mod2023/0415
Proposed Development:	Modification of Development Consent DA2021/0669 granted for Demolition works and construction of a new restaurant, car parking, and associated uses, including a Voluntary Planning Agreement.
Date:	21/09/2023
Responsible Officer	Adam Croft
Land to be developed (Address):	Lot 7005 DP 1117451 , 1193 Barrenjoey Road PALM BEACH NSW 2108 Lot 7002 DP 1117592 , 1193 Barrenjoey Road PALM BEACH NSW 2108 Lot 298 DP 721522 , 1191 Barrenjoey Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The modification application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Resilience and Hazards) 2021 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed modifications are in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.10, 2.11 and 2.12 of the CM (R & H) apply for this modification DA.

Comment:

On internal assessment, the proposed modifications satisfies requirements under clauses 2.10, 2.11 and 2.12 of the SEPP R&H. As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

Pittwater LEP 2014 and Pittwater 21 DCP

Estuarine Risk Management

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

Modifications include, among others, RL Changes to Ground floor finished level which doesn't affect 1st floor or ridge height with level raised at entry by .010 from RL 2930 to RL 2940 and level at balcony door by .025 from RL 2.930 to RL 2.955.

On internal assessment, the ground floor level for the proposed modifications are above the applicable EPL for the site. The proposed development is therefore able to satisfy the relevant estuarine risk management requirements of P21 DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

Nil.