

Proposed Fire Safety Schedule – 38 Orchard Road, Brookvale NSW 2010

	Essential Fire Safety Measures	Standard of Performance
1.	Emergency Lighting	BCA 2019 Clause E4.2, E4.4 & AS/NZS 2293.1 – 2005 Amdt 1 & 2
2.	Exit Signs	BCA 2019 Clauses E4.5, NSW E4.6 & E4.8 and AS/NZS 2293.1 – 2005 Amdt 1 & 2
3.	Fire Blankets	AS 2444 – 2001
4.	Fire Hose Reels	BCA 2019 Clause E1.4 & AS 2441 – 2005 Amdt 1
5.	Fire Hydrant System	BCA 2019 Clause E1.3 & AS 2419.1 – 2005 Amdt 1
6.	Fire Windows	BCA 2019 C3.2, C3.4, Spec. C3.4
7.	Paths of Travel	EP&A Reg 2000 Clause 186
8.	Portable Fire Extinguishers	BCA 2019 Clause E1.6 & AS 2444 – 2001
9.	Warning and Operational Signs	EP&A Reg 2000 Clause 183, BCA 2019 Clause C3.6, D2.23, E3.3 & H101.8