

## Landscape Referral Response

<b>Application Number:</b>	DA2019/0866
<b>Date:</b>	21/08/2019
<b>Responsible Officer:</b>	Kent Bull
<b>Land to be developed (Address):</b>	Lot 33 DP 225371 , 12 Springvale Avenue FRENCHS FOREST NSW 2086

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

The DA is considered acceptable with regard to the relevant controls relating to landscape issues, subject to conditions.

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Refusal comments

### Recommended Landscape Conditions:

#### CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

#### Tree protection

- (a) Existing trees which must be retained
  - i) All trees not indicated for removal on the approved plans,
  - ii) Trees located on adjoining land
- (b) Tree protection
  - i) No tree roots greater than 30mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
  - ii) All structures are to bridge tree roots greater than 30mm diameter unless directed otherwise by a qualified Arborist on site.
  - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
  - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause

E1 Private Property Tree Management and AS 4373 Pruning of amenity trees  
v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.