

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2019/0566
To:	Adam Croft
Land to be developed (Address):	Lot 2 DP 29792 , 40 Wellman Road FORESTVILLE NSW 2087

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The sedimentation drawing on sheet 1A only shows sediment fences on the side boundaries of the property. Additional fencing will need to be extended across the site to the north of the construction area, to prevent erosion impacting on the reserve.

Referral Body Recommendation

Approval - subject to conditions

Parks, Reserves and Foreshores Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site..