

Environmental Health Referral Response - commercial use

Application Number:	DA2020/0244
Date:	15/04/2020
To:	Claire Ryan
Land to be developed (Address):	Lot 58 SP 56291 , 58 / 1 Campbell Parade MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, acupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments General Comments

Statement of Environmental Effects has been reviewed and master plans. Use as takeaway food permissible subject to conditions.

Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Registration of Food Business

The food business must be registered with the Appropriate Regulatory Authority, prior to Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from a suitably qualified person that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674:2004 Design, construction and fit out of food premises.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements.

Mechanical ventilation

Where Mechanical ventilation is required to be installed in the food premises it must comply with Australian Standard (AS) 1668.2 "The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings" Prior to any Occupation Certificate (OC) being issued, certification is to be provided by a suitably qualified person that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2.