

Natural Environment Referral Response - Riparian

Application Number:	DA2020/1635
Date:	23/12/2020
To:	Gareth David
Land to be developed (Address):	Lot 26 DP 12985 , 39 Cumberland Avenue COLLAROY NSW 2097

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application has been assessed against relevant legislation for the protection of waterways, specifically Dee Why Lagoon. The applicant must ensure appropriate sediment and erosion controls are installed prior to commencement, maintained throughout the life of the works and removed only once sufficient groundcover has been established.

With the application of these conditions it is considered unlikely that this application will have an adverse impact on the integrity and resilience of the biophysical, ecological and hydrological environment of Dee Why Lagoon. It is therefore recommended for approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.