

---

<b>Sent:</b>	21/02/2022 4:11:29 PM
<b>Subject:</b>	NSW RFS Determination - Your Reference - DA2021-0212 (CNR-19692)
<b>Attachments:</b>	DA20210330001208-S4.55-1 - 21-02-2022 15_41_51 - Determination Letter.pdf;



## NSW RURAL FIRE SERVICE

**Attention:** Northern Beaches Council

**Your Reference:** DA2021-0212 (CNR-19692)

**Application Details:** s100B – SFPP – S4.55

**Site Address:**

5 Skyline Place  
Frenchs Forest NSW 2086

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Craig Casey on 1300 NSW RFS and quote DA20210330001208-S4.55-1.



Planning and Environment Services

**NSW RURAL FIRE SERVICE**

Locked Bag 17 Granville NSW 2142

**P** 1300 NSW RFS **E** [records@rfs.nsw.gov.au](mailto:records@rfs.nsw.gov.au)

[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au) | [www.facebook.com/nswrfs](https://www.facebook.com/nswrfs) | [www.twitter.com/nswrfs](https://www.twitter.com/nswrfs)

**PREPARE. ACT. SURVIVE.**



## NSW RURAL FIRE SERVICE

Northern Beaches Council  
PO Box 882  
MONA VALE NSW 1660

Your reference: DA2021-0212 (CNR-19692)  
Our reference: DA20210330001208-S4.55-1

**ATTENTION:** Northern Beaches Council

Date: Monday 21 February 2022

Dear Sir/Madam,

**Integrated Development Application**  
**s100B – SFPP – Seniors Housing**  
**5 Skyline Place Frenchs Forest NSW 2086, 101//DP1209504**

I refer to your correspondence dated 11/01/2022 seeking general terms of approval for the above Integrated Development in accordance with s4.55 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the submitted amended information. General Terms of Approval are now re-issued, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions.

### **Asset Protection Zones**

***Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.***

1. From the start of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire property must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

1

#### **Postal address**

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### **Street address**

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

**T** (02) 8741 5555  
**F** (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

### **Construction Standards**

***Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.***

2. New construction must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

### **Water and Utility Services**

***Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.***

3. The provision of water, electricity and gas must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
  - a) lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
  - b) no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 Guideline for Managing Vegetation Near Power Lines.
    - reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
    - reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - The storage and handling of LP Gas, the requirements of relevant authorities, and metal piping is used;
    - all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
    - connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
    - above-ground gas service pipes are metal, including and up to any outlets.

### **Landscaping Assessment**

***The intent of measures is for landscaping. To achieve this, the following conditions must apply:***

4. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area, suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity of the building;
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;

- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
- Avoid climbing species to walls and pergolas;
- Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
- Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
- Low flammability vegetation species are used.

### **Emergency and Evacuation Planning Assessment**

***Intent of measures: to provide suitable emergency and evacuation arrangements for occupants of SFPP developments.***

5. A Bush Fire Emergency Management and Evacuation Plan must be prepared and be consistent with the NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan. The Bush Fire Emergency Management and Evacuation Plan should include planning for the early relocation of occupants. A copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to occupation of the development.

This letter is in response to an assessment of the application based on the submitted further information and supersedes our previous general terms of approval dated 17/05/2021.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese  
**Supervisor Development Assessment & Plan  
Built & Natural Environment**



NSW RURAL FIRE SERVICE

# BUSH FIRE SAFETY AUTHORITY

SFPP – Seniors Housing  
5 Skyline Place Frenchs Forest NSW 2086, 101//DP1209504  
RFS Reference: DA20210330001208-S4.55-1  
Your Reference: DA2021-0212 (CNR-19692)

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority supersedes the previous Bush Fire Safety Authority DA20210330001208-Original-1 issued on 17/05/2021 and confirms that, subject to the attached reissued General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

**Kalpana Varghese**

**Supervisor Development Assessment & Plan  
Built & Natural Environment**

Monday 21 February 2022